



1155 Kelly Johnson Blvd., Suite 305
Colorado Springs, CO 80920
719.900.7220 • GallowayUS.com

8/25/2022

Kari Parsons
El Paso County Planning & Community Development
2880 International Circle
Colorado Springs, CO 80910

RE: El Paso County – Stormwater Detention & Infiltration Design Data Worksheet

Dear Ms. Parsons,

This letter will be submitted in lieu of the standard El Paso County Stormwater Detention & Infiltration Design Data Worksheet. Additionally, this letter is to show that the Falcon Meadows at Bent Grass Filing No. 3 is exempt from providing the SDI Worksheet.

The purpose of the SDI Worksheet is to provide proof of compliance with CRS 37-92-602(8)(b)(I)(A). The proposed project in question, "Falcon Meadows at Bent Grass Filing No. 3" does not propose any **permanent** sediment basins, extended detention basins, nor sand filters. Therefore, the SDI Worksheet is not required.

All runoff will be treated using existing extended detention basins that were constructed with Falcon Meadows at Bent Grass Filing No. 1 & 2. This will act as water quality treatment after Final Stabilization. Therefore, we have included specific notes on the GEC Plans and SWMP to inform the contractor that frequent cleaning of this existing facility will be paramount during construction.

We hope that this resolves any questions that will come up from County Staff regarding the project. If you have any questions regarding the information provided, please feel free to reach out to us at (719) 900-7220.

Sincerely,
GALLOWAY

Grant Dennis, PE
Project Manager
GrantDennis@GallowayUS.com

