



Prevent • Promote • Protect

Environmental Health Division
1675 W. Garden of the Gods Road
Suite 2044
Colorado Springs, CO 80907
(719) 578-3199 *phone*
(719) 578-3188 *fax*
www.elpasocountyhealth.org

2020 N. Ellicott-Cordero, Filing No. 2 Rezone, P-23-2

Please accept the following comments from El Paso County Public Health (EPCPH) regarding the 16.6-acre, 3-residential lot rezone project referenced above:

- **There are no El Paso County Public Health issues noted with the proposed rezone.**
- **Each lot developed must have an approved Onsite Wastewater Treatment System (OWTS). A soils report is required for review, but is not required for the rezone submittal or approval.**
- **A finding for sufficiency in terms of water quality cannot be made at this time, nor is it required for the rezone approval.**

Mike McCarthy
El Paso County Public Health
mikemccarthy@elpasoco.com
719-332-5771
23June2023