

Marc Whorton

From: Delroy Johnson <Djohnson@norwood.dev>
Sent: Tuesday, April 6, 2021 4:32 PM
To: Marc Whorton
Subject: Fwd: Message from KM_C364e


Marc, see below and attached, the fire department has approved the design, you may just have to show the 20 foot and 70 foot as per his very last example, and I am assuming that is unpaved. So we would just have 12 feet of that paved.

Sent from my iPhone


Begin forwarded message:

From: Scott Ridings <sridings@wescottfire.org>
Date: April 6, 2021 at 4:19:27 PM MDT
To: Delroy Johnson <Djohnson@norwood.dev>
Subject: Re: Message from KM_C364e


Please see the attached, anyone would be acceptable.




96' DIAMETER
CUL-DE-SAC




60' "Y"



MINIMUM CLEARANCE
AROUND A FIRE
HYDRANT



120' HAMMERHEAD



ACCEPTABLE ALTERNATIVE
TO 120' HAMMERHEAD