

October 27, 2022

Kari Parsons El Paso County Development Services Department 2880 International Circle, Suite 110 Colorado Springs, CO 80910-3127

 RE: Waterview East Commercial - Preliminary Plan Sec. 9, Twp. 15S, Rng. 65W, 6th P.M.
Water Division 2, Water Districts 10
CDWR Assigned Subdivision No. 30517

To Whom It May Concern:

We have received the above-referenced proposal to subdivide an existing 22.1-acre tract of land into 9 commercial lots and irrigated green space. According to the submittal, the proposed supply of water and wastewater disposal is to be served by the Widefield Water and Sanitation District ("Widefield").

Water Supply Demand

The Water Supply Information Summary, Form No. GWS-76, and Water Demand Report provided with the submittal estimates a demand of 35 acre-feet for all intended uses in the subdivision.

Source of Water Supply

The source of water for the proposed development is to be served by the Widefield Water and Sanitation District. A letter of commitment dated August 9, 2022 from Widefield was provided with the materials and indicated that <u>31.15 acre-feet</u> are committed to the proposed subdivision. The letter also notes Widefield's commitment to provide wastewater disposal.

According to the records of this office, Widefield has sufficient water resources to supply this development as described above.

Additional Comments

Should the development include construction and/or modification of any storm water structure(s), the Applicant should be aware that, unless the storm water structure(s) can meet the requirements of a "storm water detention and infiltration facility" as defined in section 37-92-602(8), Colorado Revised Statutes, the structure may be subject to administration by this office. The applicant should review DWR's Administrative Statement Regarding the Management of Storm Water Detention Facilities and Post-Wildland Fire Facilities in Colorado, available online at:



Waterview East Commercial October 27, 2022 Page 2 of 2

https://dnrweblink.state.co.us/dwr/0/edoc/3576581/DWR_3576581.pdf?searchid=978a5a 31-ddf9-4e09-b58c-a96f372c943d, to ensure that the notice, construction and operation of the proposed structure meets statutory and administrative requirements.

State Engineer's Office Opinion

Pursuant to Section 30-28-136(1)(h)(II) C.R.S., it is the opinion of this office that the proposed water supply can be provided without causing injury to decreed water rights, and the supply is expected to be adequate. Should you or the applicant have questions regarding any of the above, please feel free to contact me directly.

Sincerely,

Ivan Franco, P.E. Water Resources Engineer

cc: Bill Tyner, Division 2 Engineer District 10 Water Commissioner