



Prevent • Promote • Protect

Environmental Health Division  
1675 W. Garden of the Gods Road  
Suite 2044  
Colorado Springs, CO 80907  
(719) 578-3199 *phone*  
(719) 578-3188 *fax*  
[www.elpasocountyhealth.org](http://www.elpasocountyhealth.org)

**Hanson Extended Family, AL-17-016**

**Please accept the following comments from El Paso County Public Health in support of the special use project referenced above:**

- **Water service for the existing home and the proposed 1-bedroom modular house is by an individual well.**
- **Wastewater service for the project is proposed to be a new onsite wastewater treatment system (OWTS). A New OWTS Permit is required for the system installation. All installation regulations and setbacks must be in compliance with the current OWTS regulations.**
- **The existing OWTS was originally approved for a 4 bedroom house in 1992 and the soil treatment area was repaired in 2014 with the addition of a diverter valve connecting the original soil treatment area (STA) to a new STA. As an option the proposed 1 bedroom house could be connected to the existing septic tank (or a new 1000 gallon tank) and connected to the to the existing STA upstream from the diverter valve. A Minor OWTS Repair Permit is required for this option.**

**Mike McCarthy R.E.H.S.  
El Paso County Public Health  
Environmental Health Division  
719.575.8602  
[mikemccarthy@elpasoco.com](mailto:mikemccarthy@elpasoco.com)  
27July2017**