



Prevent • Promote • Protect

Environmental Health Division
1675 W. Garden of the Gods Road
Suite 2044
Colorado Springs, CO 80907
(719) 578-3199 *phone*
(719) 578-3188 *fax*
www.elpasocountyhealth.org

Circle K, PPR-22-30

Please accept the following comments from El Paso County Public Health regarding the project referenced above:

- Water service will be provided by Woodmen Hills Metropolitan District. The water system is assigned the PWSID #CO0121930 from the Colorado Department of Public Health and Environment.
- Wastewater service to be provided by Woodmen Hills Metropolitan District.
- El Paso County Public Health requires retail food service establishment interior finish plans to be submitted for review and approval prior to commencement of construction.
- Earthmoving activity more than one acre, but less than twenty-five acres, requires a local Construction Activity Permit from El Paso County Public Health. Go to <https://www.elpasocountyhealth.org/service/air-quality/construction-activity-application> for more information. A Demolition Permit from El Paso County Public Health will be required prior the existing structures demolition.
- The water quality basin must have mosquito control responsibilities included as a part of the construction design and maintenance plan to help control mosquito breeding habitat and minimize the potential for West Nile Virus.

Mike McCarthy
El Paso County Public Health
719-332-5771
mikemccarthy@elpasoco.com
23July2022 (Revised 30Jan2023)