








ENG-CDR19002-R3-SWMP Summary_Markup Summary

5 (1)		
	Subject: Engineer Page Index: 5 Date: 5/5/2020 8:54:51 AM Author: CFurchak Color:  Layer: Space: Page Label: 5	change to "and an" Unresolved.

7 (1)		
	Subject: Engineer Page Index: 7 Date: 5/5/2020 11:11:36 AM Author: CFurchak Color:  Layer: Space: Page Label: 7	add installing access roads

8 (2)		
	Subject: Engineer Page Index: 8 Date: 5/5/2020 1:17:19 PM Author: CFurchak Color:  Layer: Space: Page Label: 8	update SWMP with findings

	Subject: Engineer Page Index: 8 Date: 5/5/2020 11:17:22 AM Author: CFurchak Color:  Layer: Space: Page Label: 8	address general locations Unresolved.

10 (1)		
	Subject: Engineer Page Index: 10 Date: 5/5/2020 12:47:12 PM Author: CFurchak Color:  Layer: Space: Page Label: 10	Where? not shown on CDs



Subject: Engineer
Page Index: 11
Date: 5/5/2020 10:22:29 AM
Author: CFurchak
Color:
Layer:
Space:
Page Label: 11

move to Section 2. non-structural BMPs

Add VTC to reduce soil tracking

Subject: Engineer
Page Index: 11
Date: 5/5/2020 10:23:24 AM
Author: CFurchak
Color:
Layer:
Space:
Page Label: 11

Add VTC to reduce soil tracking

Proposed	Reviewed	Approved
Cast-in-place concrete is not anticipated to complete the part of the work.		
State that no batch plants are proposed.		
Stockpiled staging area, construction fence, non-structural BMPs. Daily cleanup of staging and stockpile area to be conducted.		
Construction fence		

Subject: Engineer
Page Index: 11
Date: 5/5/2020 12:48:03 PM
Author: CFurchak
Color:
Layer:
Space:
Page Label: 11

State that no batch plants are proposed

C. Best Manager
change from "can" be used to "will" be used

Subject: Engineer
Page Index: 11
Date: 5/5/2020 12:50:57 PM
Author: CFurchak
Color:
Layer:
Space:
Page Label: 11

change from "can" be used to "will" be used

add VTC

add VTC prior to demolis same da to, const stabilize construi equipm

Subject: Engineer
Page Index: 12
Date: 5/5/2020 10:23:37 AM
Author: CFurchak
Color:
Layer:
Space:
Page Label: 12

add VTC

7. Add a bullet pointing that the QSM will sign the inspection form

Subject: Engineer
Page Index: 17
Date: 5/5/2020 1:09:51 PM
Author: CFurchak
Color:
Layer:
Space:
Page Label: 17

Add a bullet stating that the QSM will sign the inspection form