



Prevent • Promote • Protect

Environmental Health Division
1675 W. Garden of the Gods Road
Suite 2044
Colorado Springs, CO 80907
(719) 578-3199 *phone*
(719) 578-3188 *fax*
www.elpasocountyhealth.org

11810 Stapleton Road, PPR-23-22

Please accept the following comments from El Paso County Public Health regarding the project referenced above:

- Water service will be provided by Meridian Ranch Service Metropolitan District. The water system is assigned the PWSID # CO0121455 from the Colorado Department of Public Health and Environment.
- Interior finish plans for all El Paso County Public Health regulated facilities must be submitted to El Paso County Public Health for review and approval prior to commencement of the project. Contact El Paso County Public Health at 719-578-3199, option 3.
- Radon resistant construction techniques/practices are encouraged to be used in this area. The EPA has determined that Colorado, and the El Paso County area have potentially higher radon levels than other areas of the country.
- Earthmoving activity more than one acre, but less than twenty-five acres, requires a local Construction Activity Permit from El Paso County Public Health. Go to <https://www.elpasocountyhealth.org/service/air-quality/construction-activity-application> for more information.

Mike McCarthy
El Paso County Public Health
719-332-5771
mikemccarthy@elpasoco.com
02March2024