



Prevent • Promote • Protect

Environmental Health Division
1675 W. Garden of the Gods Road
Suite 2044
Colorado Springs, CO 80907
(719) 578-3199 *phone*
(719) 578-3188 *fax*
www.elpasocountyhealth.org

Barbarick Transfer Station, 8812 Cliff Allan Pt., AL-23-10

Please accept the following comments from El Paso County Public Health regarding special use project referenced above:

- A record of 1 permitted professional engineer designed Onsite Wastewater Treatment System (OWTS) issued in 2016 is on file for the existing structure on the site. The OWTS component locations must be located to assure the components of the OWTS are protected from vehicular traffic and other means of compaction.
- The OWTS must be adequate in size for the anticipated increase in demand for the proposed transfer station employees. An OWTS design engineer must provide written verification to El Paso County Public Health (EPCPH) of their review findings.
- Adequate area must be reserved on the property for a secondary site for the possibility of a repair, addition, or replacement of the existing soil treatment area.
- Earthmoving activity more than one acre, but less than twenty-five acres, requires a local Construction Activity Permit from El Paso County Public Health. Go to <https://www.elpasocountyhealth.org/service/air-quality/construction-activity-application> for more information.
- The water quality basin must have mosquito control responsibilities included as a part of the construction design and maintenance plan to help control mosquito breeding habitat and minimize the potential for West Nile Virus.
- Sufficient water must be available for dust control on the existing and planned access roads to remain compliant with Colorado Air Quality Regulations.

Mike McCarthy
El Paso County Public Health
mikemccarthy@elpasoco.com
719-332-5771
21July2023