



ORIGINAL PERMIT APPLICANT(S)

JAMES MARTENS
 KAREN LEE MARTENS

APPROVED WELL LOCATION

Water Division: 2 Water District: 10
 Designated Basin: N/A
 Management District: N/A
 County: EL PASO
 Parcel Name: N/A
 Physical Address: N/A
 SE 1/4 NW 1/4 Section 28 Township 12.0 S Range 65.0 W Sixth P.M.

UTM COORDINATES (Meters, Zone: 13, NAD83)

Easting: 528133.3 Northing: 4314358.0

PERMIT TO USE AN EXISTING WELL

ISSUANCE OF THIS PERMIT DOES NOT CONFER A WATER RIGHT
CONDITIONS OF APPROVAL

- 1) This well shall be used in such a way as to cause no material injury to existing water rights. The issuance of this permit does not ensure that no injury will occur to another vested water right or preclude another owner of a vested water right from seeking relief in a civil court action.
- 2) The construction of this well shall be in compliance with the Water Well Construction Rules 2 CCR 402-2, unless approval of a variance has been granted by the State Board of Examiners of Water Well Construction and Pump Installation Contractors in accordance with Rule 18.
- 3) Approved pursuant to CRS 37-90-137(4) on the condition that this well is operated in accordance with the augmentation plan approved by the Division 2 Water Court in Case No. 19CW3006. If the well is not operated in accordance with the terms of said decree, it will be subject to administration including orders to cease diverting water.
- 4) The use of ground water from this well is limited to ordinary household purposes inside one (1) single family dwelling, the irrigation of 9,000 square feet of home gardens and lawns and the watering of four (4) horses or equivalent livestock.
- 5) The pumping rate of this well shall not exceed 15 GPM.
- 6) The average annual amount of ground water to be withdrawn shall not exceed 0.78 acre-feet.
- 7) Production is limited to the Denver aquifer.
- 8) **CONDITION REVOKED ON 01/28/2020 REPLACED BY CONDITION #9.**
 The entire length of the hole shall be geophysically logged as required by Rule 9 of the Statewide Nontributary Ground Water Rules prior to installing casing.
- 9) This well permit approves the conversion of an existing well that was exempt to a well permitted pursuant to 37-92-137(4) and therefore subject to the Statewide Nontributary Groundwater Rules. Rule 9 requires the entire length of the borehole to be geophysically logged prior to installing casing. This well has already been constructed and cased, limiting the ability to obtain usable geophysical logs. This requirement is waived on the basis that a geophysical log would not provide DWR with data useful to administration of groundwater in this area. In the event this well is redrilled in the future, a geophysical log must be obtained in accordance with Rule 9 of the Statewide Nontributary Groundwater Rules. ADF 1/28/2020
- 10) The owner shall mark the well in a conspicuous location with well permit number(s), name of the aquifer, and court case number(s) as appropriate. The owner shall take necessary means and precautions to preserve these markings.
- 11) A totalizing flow meter must be installed on this well and maintained in good working order. Permanent records of all diversions must be maintained by the well owner (recorded at least annually) and submitted to the Division Engineer upon request.
- 12) This well shall be located not more than 200 feet from the location specified on this permit.
- 13) The return flow from the use of this well must be through an individual waste water disposal system of the type so that not less than 4% of the total amount of water withdrawn is returned to the same stream system in which the well is located.
- 14) This well is subject to administration by the Division Engineer in accordance with applicable decrees, statutes, rules, and regulations.

