



# Southmoor Ridge General Utility Report

February 2024  
HR Green Project No: 2303146

Prepared For:  
Bryan Kniep – Vice President of Operations  
DHN Development  
2335 Coralbell Grove, Unit 101  
Colorado Springs, CO 80910  
(719) 244-9851

Prepared By:  
Richie Lyon, PE  
Project Manager  
HR Green Development, LLC  
1975 Research Parkway  
Colorado Springs, CO 80920



# Table of Contents

- A. Project Location and Description .....5
  - 1. Site Location .....5
  - 2. Description of Property and Land Use .....5
- B. Calculated Water Demands .....6
  - 1. Average Day Demands (ADD) .....6
  - 2. Max Day Demands (MDD) .....6
  - 3. Peak Hour Demands (PHD) .....7
  - 4. Irrigation Demands .....7
- C. Existing Water System .....7
  - 1. Existing Distribution System .....7
- D. Proposed Water System .....7
  - 1. Proposed Distribution System .....7
  - 2. Required Fire Flows .....8
- E. Proposed Water System Analysis and Modeling .....8
  - 1. Hydraulic Model .....8
  - 2. Hydraulic Modeling Scenarios .....8
  - 3. Hydraulic Modeling Results .....8
- F. Calculated Wastewater Flows .....9
  - 1. Average Daily Wastewater Flows (ADF) .....9
  - 2. Peaking Factor .....9
  - 3. Peak Design Flows (PDF) .....10
- G. Existing Wastewater System ..... 11
  - 1. Existing Collection System .....11
- H. Proposed Wastewater System ..... 11
  - 1. Proposed Collection System .....11
- I. Proposed Wastewater System Analysis and Modeling ..... 11
  - 1. Hydraulic Models .....11
  - 2. Hydraulic Modeling Scenarios .....11
  - 3. Hydraulic Modeling Output and Required Schematics .....11
- J. References ..... 12

## Appendices

- A. Water Demands
- B. Water Storage
  - CSFD Fire Flow Requirements
- C. Water Hydraulic Analysis and Modeling
  - Average Day Scenario
  - May Day Scenario
  - Peak Hour Scenario
  - Fire Flow Scenario
- D. Wastewater Flows
- E. Wastewater Hydraulic Modeling
- F. Maps
  - Vicinity Map
  - Preliminary Utilities Plan
- G. References
  - Security Water and Sanitation District Hydrant Information
  - Security Water and Sanitation District Construction Memorandum

## A. Project Location and Description

### 1. Site Location

The Southmoor Ridge development is located within a portion of the North ½ of the Northwest ¼ of Section 24, and the Southwest ¼ of the Southwest ¼ of Section 13 within Township 15 South, Range 66 West of the 6<sup>th</sup> Principal Meridian in the City of Fountain in El Paso County, Colorado. The El Paso County numbers are 6513314015 ,6513300021, 6524200052, and 6524200053. The site is located to the east of Southmoor Drive, bisected by a planned future right-of-way extension of Fontaine Boulevard, and east of US Highway 85-87 in the City of Fountain. The area is surrounded by commercial buildings.



Figure 1: Vicinity Map

### 2. Description of Property and Land Use

The site is a parcel of approximately 16.4 acres that consists of apartment complexes, townhomes, amenity center, pool and all the relevant infrastructure for the development. Southmoor Ridge includes four apartments building, townhomes, amenity buildings (clubhouse, pool, sports court) and accessory structures such as garages. There are 210 apartment units on 1.57 acres that vary from studio to three-bedroom. The 77 townhome units cover 1.77 acres and vary from one to three-bedroom. The amenity center is 4,250 square feet and will have approximately a 1,500 square foot pool. The development will have 6.7 acres dedicated to tracts and open space – approximately 4.25 acres will be irrigated.

## B. Calculated Water Demands

### 1. Average Day Demands (ADD)

The Average Day Demand Rates were calculated per Security Water and Sanitation District Memorandum in Appendix F and supporting calculations can be found in Appendix A. The table below depicts a summary of the tabulated results.

Land Use	Dwelling Units	WSFUs	Area (SF)	ADD (GPD)	ADD (GPM)
Townhomes 1 Bedroom	9	70.2	N/A	1,268	9.72
Townhomes 2-3 Bedroom	68	775.2	N/A	14,000	0.88
Apartment Studio, 1-2 Bedroom	202	1575.6	N/A	28,455	19.76
Apartment 3 Bedroom	8	91.2	N/A	1,647	1.14
Amenity Center			4,250	2,125	1.48
Pool	N/A	N/A	1500	95	0.07
Irrigation Tap	N/A	N/A	185,130	3,794	2.63
<b>Total</b>				<b>51,384</b>	<b>36</b>

### 2. Max Day Demands (MDD)

The Max Day Demand Rates were calculated per Security Water and Sanitation District Memorandum in Appendix F and supporting calculations can be found in Appendix A. A peaking factor of 2.8 was used. The table below depicts a summary of the tabulated results.

Land Use	Dwelling Units	WSFUs	Area (SF)	MDD (GPD)	MDD (GPM)
Townhomes 1 Bedroom	9	70.2	N/A	3,550	2.47
Townhomes 2-3 Bedroom	68	775.2	N/A	39,200	27.22
Apartment Studio, 1-2 Bedroom	202	1575.6	N/A	79,674	55.33
Apartment 3 Bedroom	8	91.2	N/A	4,612	3.20
Amenity Center			4,250	5,950	4.13
Pool	N/A	N/A	1500	267	0.19
Irrigation Tap	N/A	N/A	185,130	10,624	7.38
<b>Total</b>				<b>143,876</b>	<b>100</b>

Storage requirements for the proposed development are included in Appendix B. The required storage volume for the site is 0.62 MG.

### 3. Peak Hour Demands (PHD)

The Peak Hour Demand Rates were calculated per Security Water and Sanitation District Memorandum in Appendix F and supporting calculations can be found in Appendix A. A peaking factor of 4.5 was applied. The table below depicts a summary of the tabulated results.

Land Use	Dwelling Units	WSFUs	Area (SF)	PHD (GPD)	PHD (GPM)
Townhomes 1 Bedroom	9	70.2	N/A	5,705	4.08
Townhomes 2-3 Bedroom	68	775.2	N/A	63,000	45.00
Apartment Studio, 1-2 Bedroom	202	1575.6	N/A	128,047	91.46
Apartment 3 Bedroom	8	91.2	N/A	7,412	5.29
Amenity Center			4,250	9,563	6.83
Pool	N/A	N/A	1500	430	0.31
Irrigation Tap	N/A	N/A	185,130	17,074	12.20
<b>Total</b>				<b>231,229</b>	<b>165</b>

### 4. Irrigation Demands

The Irrigation Demand was calculated per the Security Water and Sanitation District Memorandum and supporting calculations can be found in Appendix B. Irrigation was included in all demand calculations above.

## C. Existing Water System

### 1. Existing Distribution System

The proposed development will be served by Security Water and Sanitation District infrastructure. Currently, a 12-inch ductile iron main line runs along Southmoor Drive and Fontaine Blvd. The proposed Southmoor Ridge development will connect into the system in a single pressure zone, and a hydraulic model has been provided to show acceptable pressures. The development will connect into the 12-inch DIP in four separate locations which is provided in Appendix B. Existing hydrant information was provided by Security Water and Sanitation District and included in Appendix F.

## D. Proposed Water System

### 1. Proposed Distribution System

The proposed development will utilize an 8-inch DIP public loop that runs through the roads within the development. These internal lines will connect to the larger Security Water and Sanitation District infrastructure at four locations: three locations on the 12-inch the runs along Southmoor Drive and one location on the 12-inch DIP that runs along Fountain Blvd. Proposed apartment buildings and townhomes will be served by a single water meter inside of each building. The final water meter sizes will be determined at a later date. Any future development of the existing water infrastructure needed to serve this site will be the responsibility of the developer.

Currently, it is projected that 4.25 acres will be irrigated. Once landscape and irrigation plans are finalized, irrigation demands will be adjusted accordingly.

## 2. Required Fire Flows

The minimum fire flow for the water distribution system is determined to be 2,000 gpm at two hydrants. The largest building is considered construction type V-A and has a building square footage of 51,300 sq. ft. of livable space. In accordance with Colorado Springs Fire Department (CFSD) Manual and the International Fire Code (IFC), the fire flow requirement is 4,000 gpm at 20 psi residual pressure for 4 hours. Since the buildings will have a sprinkler system, the fire flow is reduced 50% to 2,000 gpm. The average spacing between hydrants must be 450 ft and the maximum distance from any point on the street or road frontage to hydrant (Engine Hose Lay) must be 225 ft.

# E. Proposed Water System Analysis and Modeling

## 1. Hydraulic Model

The proposed water system was modeled using WaterGEMs. Primary distribution lines and connections to the existing system are represented in the model. A plan view schematic exhibit of the model is included in Appendix C.

All water modeling was performed with the given HGL's at tie-in points. See table below for hydrant data used:

Hydrant ID	Hydraulic Grade Line	Static Pressure
H-48	5872.07	78
H-51	5872.03	76
H-47	5872.08	79
H-46	5872.09	81

A full report of the hydrant data provided by Security Water and Wastewater Sanitation District is provided in Appendix C. The Hazen-Williams 'C' factor of 120 was used for all pipes.

## 2. Hydraulic Modeling Scenarios

The following scenarios were modeled, and results can be found in Appendix C:

- Average Day Demand for the full build-out of the development
- Max Day Demand plus Fire Flow for the full build-out of the development
- Peak Hour Demand for the full build-out of the development

No water quality aging analysis or model has been included at this time.

## 3. Hydraulic Modeling Results

Per the Widefield Water and Wastewater System Specifications, the pressure range are as follows:

- Minimum static pressure – 35 psi
- Maximum static and dynamic pressure - 120 psi
- Minimum dynamic pressures
  - Max Daily Demand + Fire Flow – 20 psi



Acceptable velocities are noted below:

- Maximum velocity with Peak Hour Demands: 2 fps
- Maximum velocity with on a Peak Day Demand during Fire Flow Conditions: 5 fps

The total demand supplied by the model for each scenario can be found in Appendix A. The Maximum Day Demand + Fire Flow scenario was calculated by adding the required Fire Flow and the Maximum Day Demand. Although only two hydrants are required to supply the 2,000 gpm flow per CSFD, the results show that all hydrants will be able to individually supply the 2,000 gpm flow and maintain a residual pressure of 20 psi.

All modeled scenarios fall within the acceptable pressure ranges. Schematics and junction and pipe reports are located in Appendix C.

## F. Calculated Wastewater Flows

### 1. Average Daily Wastewater Flows (ADF)

It is safe to assume that all water demands (excluding irrigation) will in turn be used as expected wastewater flow. Typical values for wastewater ADFs according to land use were taken from the Security Water and Sanitation District Memorandum that was provided:

- Townhomes
  - 1 Bedroom = 141 gpd/unit
  - 2-3 Bedroom = 206 gpd/unit
- Apartments
  - Studio, and 1 to 2 Bedroom = 141 gpd/unit
  - 3 Bedroom = 206 gpd/unit
- Amenity Center = 0.1 gpd/square-foot
- Pool = 95.46 gpd/ unit

Land Use	ADF (gpm)	ADF (gpd)	ADF (cfs)
Apartments	20.9	30,102	0.047
Townhomes	10.6	15,268	0.024
Amenity Clubhouse	1.5	2,125	0.003
Pool	0.1	95	0.0001

### 2. Peaking Factor

The peaking factor (PF) is defined by the following equation,  $PF = 5 \times (ADF)^{-0.168}$  where ADF is expressed in million gallons per day. The maximum PF is 5.0. The PF was calculated 5.0 for this site, please see Appendix D for complete calculations.

### 3. Peak Design Flows (PDF)

The following expression was used for calculating peak design flow (PDF),  $PDF = (ADF \times PF) + (0.1 \times ADF)$ .

Land Use	PDF (gpm)	PDF (gpd)	PDF (cfs)
Apartments	106.6	153,520	0.238
Townhomes	54.1	77,865	0.120
Amenity Clubhouse	7.5	10,838	0.017
Pool	0.3	487	0.001

## G. Existing Wastewater System

### 1. Existing Collection System

The proposed sanitary sewer network for the site will connect to an existing 12-in main line running through the development from west to east. This line ultimately runs to the City of Fountain Wastewater Treatment Facility.

## H. Proposed Wastewater System

### 1. Proposed Collection System

The proposed sanitary sewer system will be located in the internal private drives with services for the townhomes, apartment buildings and amenity center. Per Security Water and Sanitation District Standards, a minimum of 8-in sanitary sewer main will convey wastewater from the residential buildings and amenity center and connect into the existing 12-inch main in two locations.

No lift stations, force mains, or pretreatment are anticipated to be required at this time. A separate sanitary service (grease interceptor) is not needed.

## I. Proposed Wastewater System Analysis and Modeling

### 1. Hydraulic Models

Bentley FlowMaster was utilized for all wastewater hydraulic calculations associated with the Southmoor Ridge site. Primary collection lines were modeled at this time. Additional downstream segments will be modeled upon request.

### 2. Hydraulic Modeling Scenarios

Peak Design Flow calculations for the full build-out condition are included in Appendix E.

### 3. Hydraulic Modeling Output and Required Schematics

Pipe segment tabulation is included in Appendix E. Pipe slopes are set at the minimum allowable at slope of 1.0% per the Security Widefield Water and Wastewater System Standard Specifications. Proposed 8-in pipes are well under the maximum percentage full of 75%.

## J. References

1. Water and Wastewater System Standard Specification, Widefield Water and Sanitation District, January 2019

APPENDIX A  
WATER DEMANDS

## DOMESTIC WATER DEMAND GENERATION



Project #: 2303146  
 Project: Southmoor Ridge  
 Location: Fountain, CO  
 Plan Date:

By: C Budge  
 Checked:  
 Date: 2/15/2024

**UNIT DEMANDS**

**PEAKING FACTORS**

<b>TOWNHOMES</b>			24.70	WSFU/SFE	0.5 AAF/SFE	MAX. DAY / AVG. DAY	2.8
1-BEDROOM	7.8	WSFU/UNIT			446 GPD/SFE	PEAK HOUR / FLOW RATIO	4.5
2-3 BEDROOM	11.4	WSFU/UNIT			0.31 GPM/SFE		
<b>APARTMENTS</b>							
STUDIO, 1-2 BEDROOM	7.8	WSFU/UNIT	0.32	SFE/UNIT			
THREE-BEDROOM	11.4	WSFU/UNIT	0.46	SFE/UNIT			
<b>AMENITY CENTER</b>	0.5	GPD/SF	0.00	SFE/SF			
<b>POOL</b>	0.1	AAF/UNIT	95.46	GPD/UNIT			
<b>IRRIGATION</b>	893	GPD/IRR. ACRE					

BUILDING TYPE	DWELLING UNITS	WATER SERVICE FIXTURE UNITS	TOTAL SQUARE-FEET	SINGLE FAMILY EQUIVALENT UNITS	AVERAGE DAY DEMAND (ADD)		MAXIMUM DAY DEMAND (MDD)		PEAK HOUR DEMAND (PHD)	
					GPD	GPM	GPD	GPM	GPD	GPM
TOWNHOMES 2-3 BEDROOM	68	775.2	N/A	31.4	14,000	9.72	39,200	27.22	63,000	45.00
TOWNHOMES 1 BEDROOM	9	70.2	N/A	2.8	1,268	0.88	3,550	2.47	5,705	4.08
APARTMENT STUDIO, 1-2 BEDROOM	202	1575.6	N/A	63.8	28,455	19.76	79,674	55.33	128,047	91.46
APARTMENT 3 BEDROOM	8	91.2	N/A	3.7	1,647	1.14	4,612	3.20	7,412	5.29
AMENITY CENTER	N/A	N/A	4,250	5.3	2,125	1.48	5,950	4.13	9,563	6.83
POOL	N/A	N/A	1,500	0.2	95	0.07	267	0.19	430	0.31
IRRIGATION	N/A	N/A	185,130	N/A	3,794	2.63	10,624	7.38	17,074	12.20
		<b>2512.2</b>		<b>107</b>	<b>51,384</b>	<b>36</b>	<b>143,876</b>	<b>100</b>	<b>231,229</b>	<b>165</b>

APPENDIX B  
WATER STORAGE

**APPENDIX B**

IFC TABLE B105.1(2) MINIMUM REQUIRED FIRE-FLOW AND FLOW DURATION FOR BUILDINGS

FIRE-FLOW CALCULATION AREA (square feet)					FIRE-FLOW (gallons per minute) <sup>b</sup>	FLOW DURATION (hours)
Type IA and IB <sup>a</sup>	Type IIA and IIIA <sup>a</sup>	Type IV and V-A <sup>a</sup>	Type IIB and IIIB <sup>a</sup>	Type V-B <sup>a</sup>		
0-22,700	0-12,700	0-8,200	0-5,900	0-3,600	1,500	2
22,701-30,200	12,701-17,000	8,201-10,900	5,901-7,900	3,601-4,800	1,750	
30,201-38,700	17,001-21,800	10,901-12,900	7,901-9,800	4,801-6,200	2,000	
38,701-48,300	21,801-24,200	12,901-17,400	9,801-12,600	6,201-7,700	2,250	
48,301-59,000	24,201-33,200	17,401-21,300	12,601-15,400	7,701-9,400	2,500	
59,001-70,900	33,201-39,700	21,301-25,500	15,401-18,400	9,401-11,300	2,750	
70,901-83,700	39,701-47,100	25,501-30,100	18,401-21,800	11,301-13,400	3,000	3
83,701-97,700	47,101-54,900	30,101-35,200	21,801-25,900	13,401-15,600	3,250	
97,701-112,700	54,901-63,400	35,201-40,600	25,901-29,300	15,601-18,000	3,500	
112,701-128,700	63,401-72,400	40,601-46,400	29,301-33,500	18,001-20,600	3,750	4
128,701-145,900	72,401-82,100	46,401-52,500	33,501-37,900	20,601-23,300	4,000	
145,901-164,200	82,101-92,400	52,501-59,100	37,901-42,700	23,301-26,300	4,250	
164,201-183,400	92,401-103,100	59,101-66,000	42,701-47,700	26,301-29,300	4,500	
183,401-203,700	103,101-114,600	66,001-73,300	47,701-53,000	29,301-32,600	4,750	
203,701-225,200	114,601-126,700	73,301-81,100	53,001-58,600	32,601-36,000	5,000	
225,201-247,700	126,701-139,400	81,101-89,200	58,601-65,400	36,001-39,600	5,250	
247,701-271,200	139,401-152,600	89,201-97,700	65,401-70,600	39,601-43,400	5,500	
271,201-295,900	152,601-166,500	97,701-106,500	70,601-77,000	43,401-47,400	5,750	
295,901-Greater	166,501-Greater	106,501-115,800	77,001-83,700	47,401-51,500	6,000	
-	-	115,801-125,500	83,701-90,600	51,501-55,700	6,250	
-	-	125,501-135,500	90,601-97,900	55,701-60,200	6,500	
-	-	135,501-145,800	97,901-106,800	60,201-64,800	6,750	
-	-	145,801-156,700	106,801-113,200	64,801-69,600	7,000	
-	-	156,701-167,900	113,201-121,300	69,601-74,600	7,250	
-	-	167,901-179,400	121,301-129,600	74,601-79,800	7,500	
-	-	179,401-191,400	129,601-138,300	79,801-85,100	7,750	
-	-	191,401-Greater	138,301-Greater	85,101-Greater	8,000	

For SI: 1 square foot = 0.0929 m<sup>2</sup>, 1 gallon per minute = 3.785 L/m, 1 pound per square inch = 6.895 kPa.

a. Types of construction are based on the *International Building Code*.

b. Measured at 20 psi residual pressure.

**Exception: A reduction in required fire-flow of 50 percent, as *approved*, is allowed when the building is equipped with an *approved automatic sprinkler system*.**





## STORAGE REQUIREMENTS

Project #: 2303146  
Project: Southmoor Ridge  
Location: Fountain, CO  
Plan Date:

By: C Budge  
Checked:  
Date: 2/15/2024

Storage Volume (MG) = Maximum Day Demand (MG) + Fire Flow (MG)

### Maximum Day Demand (MDD)

100 GPM  
143,876 Gal

### Fire Flow (FF)

2,000 GPM  
4 hr  
480,000 Gal


### Storage Volume

0.62 MG

## APPENDIX C

# WATER HYDRAULIC ANALYSIS AND MODELING

# Southmoor Ridge



**Southmoor Ridge**  
**FlexTable: Pipe Table**  
**Active Scenario: ADD**

Label	Length (Scaled) (ft)	Start Node	Stop Node	Diameter (in)	Material	Hazen-Williams C	Flow (gpm)	Velocity (ft/s)
P-1	98	J-1	R-2	8.0	DIP	120.0	-31	0.20
P-2	258	J-3	J-1	8.0	DIP	120.0	3	0.02
P-3	81	J-4	R-4	8.0	DIP	120.0	-39	0.25
P-4	94	J-7	J-5	8.0	DIP	120.0	4	0.03
P-5	136	J-6	J-7	8.0	DIP	120.0	-10	0.06
P-6	135	J-7	J-8	8.0	DIP	120.0	4	0.03
P-7	243	R-5	J-9	8.0	DIP	120.0	-32	0.21
P-8	25	J-9	H-3	8.0	DIP	120.0	0	0.00
P-9	97	J-9	J-10	8.0	DIP	120.0	-32	0.21
P-10	27	J-10	H-4	8.0	DIP	120.0	0	0.00
P-11	64	J-10	J-11	8.0	DIP	120.0	-32	0.21
P-12	70	J-11	J-12	8.0	DIP	120.0	5	0.03
P-13	7	J-13	H-5	8.0	DIP	120.0	0	0.00
P-17	71	J-16	J-2	8.0	DIP	120.0	29	0.18
P-18	21	J-16	J-17	8.0	DIP	120.0	5	0.03
P-19	26	J-2	J-18	8.0	DIP	120.0	-15	0.10
P-20	9	J-18	H-7	8.0	DIP	120.0	0	0.00
P-22	23	J-19	J-2	8.0	DIP	120.0	-44	0.28
P-23	32	J-19	J-20	8.0	DIP	120.0	5	0.03
P-24	107	J-18	J-21	8.0	DIP	120.0	-15	0.10
P-25	56	J-21	J-22	8.0	DIP	120.0	2	0.01
P-26	97	J-21	J-23	8.0	DIP	120.0	-17	0.11
P-27	6	J-23	H-8	8.0	DIP	120.0	0	0.00
P-29	42	J-24	J-25	8.0	DIP	120.0	5	0.03
P-30	12	J-23	J-24	8.0	DIP	120.0	-17	0.11
P-32	23	J-3	J-28	8.0	DIP	120.0	-25	0.16
P-33	10	J-28	H-10	8.0	DIP	120.0	0	0.00
P-35	45	J-30	J-31	8.0	DIP	120.0	1	0.00
P-36	162	J-30	J-32	8.0	DIP	120.0	-26	0.16
P-37	43	J-32	J-33	8.0	DIP	120.0	0	0.00
P-38	62	J-32	J-34	8.0	DIP	120.0	-26	0.17
P-39	45	J-34	J-35	8.0	DIP	120.0	1	0.00
P-40	73	J-34	J-36	8.0	DIP	120.0	-27	0.17
P-41	44	J-36	J-37	8.0	DIP	120.0	1	0.00
P-42	73	J-36	J-38	8.0	DIP	120.0	-27	0.17
P-43	44	J-38	J-39	8.0	DIP	120.0	1	0.00
P-44	59	J-6	J-40	8.0	DIP	120.0	-18	0.11
P-45	43	J-40	J-41	8.0	DIP	120.0	0	0.00
P-46	66	J-40	J-42	8.0	DIP	120.0	-18	0.12
P-47	44	J-42	J-43	8.0	DIP	120.0	1	0.00
P-48	79	J-42	J-44	8.0	DIP	120.0	-19	0.12
P-49	232	J-44	J-4	8.0	DIP	120.0	-19	0.12
P-50	44	J-44	J-45	8.0	DIP	120.0	1	0.00
P-51	74	J-5	J-46	8.0	DIP	120.0	1	0.00
P-52	61	J-5	J-47	8.0	DIP	120.0	4	0.02
P-53	73	J-47	J-48	8.0	DIP	120.0	1	0.00
P-54	67	J-47	J-49	8.0	DIP	120.0	3	0.02
P-55	113	J-49	R-3	8.0	DIP	120.0	3	0.02
P-56	71	J-49	J-50	8.0	DIP	120.0	1	0.00
P-57	73	J-51	J-7	8.0	DIP	120.0	18	0.12
P-58	70	J-51	J-52	8.0	DIP	120.0	1	0.00
P-59	75	J-53	J-51	8.0	DIP	120.0	19	0.12
P-60	72	J-53	J-54	8.0	DIP	120.0	1	0.00

**Southmoor Ridge**  
**FlexTable: Pipe Table**  
**Active Scenario: ADD**

Label	Length (Scaled) (ft)	Start Node	Stop Node	Diameter (in)	Material	Hazen-Williams C	Flow (gpm)	Velocity (ft/s)
P-61	142	J-4	J-55	8.0	DIP	120.0	20	0.13
P-62	78	J-55	J-53	8.0	DIP	120.0	20	0.12
P-63	72	J-55	J-56	8.0	DIP	120.0	1	0.00
P-64	42	H-2	J-57	8.0	DIP	120.0	0	0.00
P-65	42	J-57	J-58	8.0	DIP	120.0	1	0.00
P-66	66	J-57	J-59	8.0	DIP	120.0	-1	0.00
P-67	43	J-59	J-60	8.0	DIP	120.0	1	0.00
P-68	28	J-59	J-61	8.0	DIP	120.0	-1	0.01
P-69	61	J-61	J-8	8.0	DIP	120.0	-2	0.01
P-70	66	J-61	J-62	8.0	DIP	120.0	1	0.00
P-71	48	J-8	J-63	8.0	DIP	120.0	2	0.02
P-72	66	J-63	J-64	8.0	DIP	120.0	1	0.00
P-73	25	J-63	J-65	8.0	DIP	120.0	2	0.01
P-74	39	J-65	J-66	8.0	DIP	120.0	0	0.00
P-75	69	J-65	J-68	8.0	DIP	120.0	1	0.01
P-77	43	J-68	J-67	8.0	DIP	120.0	1	0.00
P-78	18	J-11	J-69	8.0	DIP	120.0	-38	0.24
P-79	106	J-69	J-13	8.0	DIP	120.0	-39	0.25
P-81	48	J-38	H-12	8.0	DIP	120.0	-28	0.18
P-82	31	H-12	J-6	8.0	DIP	120.0	-28	0.18
P-83	146	J-69	J-70	8.0	DIP	120.0	2	0.01
P-84	17	J-1	J-71	8.0	DIP	120.0	34	0.22
P-85	66	J-71	J-16	8.0	DIP	120.0	34	0.22
P-86	33	J-71	H-11	8.0	DIP	120.0	0	0.00
P-87	160	J-13	J-19	8.0	DIP	120.0	-39	0.25
P-88	175	J-3	J-24	8.0	DIP	120.0	22	0.14
P-89	56	J-30	J-28	8.0	DIP	120.0	25	0.16
P-90	38	J-68	J-72	8.0	DIP	120.0	1	0.01
P-91	14	J-72	H-1	8.0	DIP	120.0	0	0.00

**Southmoor Ridge**  
**FlexTable: Junction Table**  
**Active Scenario: ADD**

Label	Elevation (ft)	Demand (gpm)	Hydraulic Grade (ft)	Pressure (psi)
J-1	5,687.96	0	5,872.07	80
J-2	5,686.25	0	5,872.06	80
J-3	5,686.39	0	5,872.07	80
J-4	5,679.55	0	5,872.09	83
J-5	5,683.37	0	5,872.08	82
J-6	5,683.40	0	5,872.08	82
J-7	5,682.46	0	5,872.08	82
J-8	5,681.19	0	5,872.08	83
J-9	5,689.18	0	5,872.04	79
J-10	5,688.28	0	5,872.04	80
J-11	5,687.70	0	5,872.04	80
J-12	5,690.50	5	5,872.04	79
J-13	5,687.15	0	5,872.05	80
J-16	5,686.72	0	5,872.06	80
J-17	5,687.00	5	5,872.06	80
J-18	5,685.69	0	5,872.06	81
J-19	5,686.23	0	5,872.06	80
J-20	5,688.50	5	5,872.06	79
J-21	5,684.94	0	5,872.06	81
J-22	5,686.50	2	5,872.06	80
J-23	5,684.43	0	5,872.06	81
J-24	5,684.43	0	5,872.06	81
J-25	5,686.50	5	5,872.06	80
J-28	5,686.41	0	5,872.07	80
J-30	5,686.77	0	5,872.07	80
J-31	5,685.95	1	5,872.07	81
J-32	5,686.02	0	5,872.07	80
J-33	5,686.06	0	5,872.07	80
J-34	5,685.30	0	5,872.07	81
J-35	5,684.86	1	5,872.07	81
J-36	5,684.72	0	5,872.08	81
J-37	5,684.50	1	5,872.08	81
J-38	5,684.13	0	5,872.08	81
J-39	5,683.88	1	5,872.08	81
J-40	5,682.88	0	5,872.08	82
J-41	5,683.46	0	5,872.08	82
J-42	5,682.29	0	5,872.08	82
J-43	5,682.96	1	5,872.08	82
J-44	5,681.64	0	5,872.08	82
J-45	5,682.32	1	5,872.08	82
J-46	5,683.82	1	5,872.08	81
J-47	5,683.96	0	5,872.08	81
J-48	5,684.54	1	5,872.08	81
J-49	5,684.65	0	5,872.08	81
J-50	5,685.32	1	5,872.08	81
J-51	5,681.86	0	5,872.08	82
J-52	5,682.32	1	5,872.08	82
J-53	5,681.25	0	5,872.08	83
J-54	5,681.68	1	5,872.08	82
J-55	5,680.62	0	5,872.08	83
J-56	5,681.05	1	5,872.08	83
J-57	5,682.42	0	5,872.08	82
J-58	5,682.99	1	5,872.08	82

**Southmoor Ridge**  
**FlexTable: Junction Table**  
**Active Scenario: ADD**

Label	Elevation (ft)	Demand (gpm)	Hydraulic Grade (ft)	Pressure (psi)
J-59	5,681.92	0	5,872.08	82
J-60	5,682.38	1	5,872.08	82
J-61	5,681.68	0	5,872.08	82
J-62	5,681.38	1	5,872.08	83
J-63	5,681.23	0	5,872.08	83
J-64	5,680.77	1	5,872.08	83
J-65	5,681.25	0	5,872.08	83
J-66	5,681.50	0	5,872.08	82
J-67	5,680.91	1	5,872.08	83
J-68	5,680.71	0	5,872.08	83
J-69	5,687.70	0	5,872.05	80
J-70	5,688.70	2	5,872.05	79
J-71	5,687.70	0	5,872.07	80
J-72	5,680.40	1	5,872.08	83

**Southmoor Ridge**  
**FlexTable: Pipe Table**  
**Active Scenario: MDD**

Label	Length (Scaled) (ft)	Start Node	Stop Node	Diameter (in)	Material	Hazen-Williams C	Flow (gpm)	Velocity (ft/s)
P-1	98	J-1	R-2	8.0	DIP	120.0	-57	0.36
P-2	258	J-3	J-1	8.0	DIP	120.0	-7	0.04
P-3	81	J-4	R-4	8.0	DIP	120.0	-46	0.29
P-4	94	J-7	J-5	8.0	DIP	120.0	-10	0.06
P-5	136	J-6	J-7	8.0	DIP	120.0	-16	0.10
P-6	135	J-7	J-8	8.0	DIP	120.0	12	0.07
P-7	243	R-5	J-9	8.0	DIP	120.0	-18	0.11
P-8	25	J-9	H-3	8.0	DIP	120.0	0	0.00
P-9	97	J-9	J-10	8.0	DIP	120.0	-18	0.11
P-10	27	J-10	H-4	8.0	DIP	120.0	0	0.00
P-11	64	J-10	J-11	8.0	DIP	120.0	-18	0.11
P-12	70	J-11	J-12	8.0	DIP	120.0	15	0.09
P-13	7	J-13	H-5	8.0	DIP	120.0	0	0.00
P-17	71	J-16	J-2	8.0	DIP	120.0	35	0.23
P-18	21	J-16	J-17	8.0	DIP	120.0	15	0.09
P-19	26	J-2	J-18	8.0	DIP	120.0	-15	0.09
P-20	9	J-18	H-7	8.0	DIP	120.0	0	0.00
P-22	23	J-19	J-2	8.0	DIP	120.0	-50	0.32
P-23	32	J-19	J-20	8.0	DIP	120.0	14	0.09
P-24	107	J-18	J-21	8.0	DIP	120.0	-15	0.09
P-25	56	J-21	J-22	8.0	DIP	120.0	4	0.03
P-26	97	J-21	J-23	8.0	DIP	120.0	-19	0.12
P-27	6	J-23	H-8	8.0	DIP	120.0	0	0.00
P-29	42	J-24	J-25	8.0	DIP	120.0	14	0.09
P-30	12	J-23	J-24	8.0	DIP	120.0	-19	0.12
P-32	23	J-3	J-28	8.0	DIP	120.0	-26	0.17
P-33	10	J-28	H-10	8.0	DIP	120.0	0	0.00
P-35	45	J-30	J-31	8.0	DIP	120.0	2	0.01
P-36	162	J-30	J-32	8.0	DIP	120.0	-29	0.18
P-37	43	J-32	J-33	8.0	DIP	120.0	1	0.01
P-38	62	J-32	J-34	8.0	DIP	120.0	-30	0.19
P-39	45	J-34	J-35	8.0	DIP	120.0	2	0.01
P-40	73	J-34	J-36	8.0	DIP	120.0	-31	0.20
P-41	44	J-36	J-37	8.0	DIP	120.0	2	0.01
P-42	73	J-36	J-38	8.0	DIP	120.0	-33	0.21
P-43	44	J-38	J-39	8.0	DIP	120.0	2	0.01
P-44	59	J-6	J-40	8.0	DIP	120.0	-18	0.12
P-45	43	J-40	J-41	8.0	DIP	120.0	1	0.01
P-46	66	J-40	J-42	8.0	DIP	120.0	-20	0.13
P-47	44	J-42	J-43	8.0	DIP	120.0	2	0.01
P-48	79	J-42	J-44	8.0	DIP	120.0	-21	0.14
P-49	232	J-44	J-4	8.0	DIP	120.0	-23	0.15
P-50	44	J-44	J-45	8.0	DIP	120.0	2	0.01
P-51	74	J-5	J-46	8.0	DIP	120.0	2	0.01
P-52	61	J-5	J-47	8.0	DIP	120.0	-11	0.07
P-53	73	J-47	J-48	8.0	DIP	120.0	2	0.01
P-54	67	J-47	J-49	8.0	DIP	120.0	-13	0.08
P-55	113	J-49	R-3	8.0	DIP	120.0	-14	0.09
P-56	71	J-49	J-50	8.0	DIP	120.0	2	0.01
P-57	73	J-51	J-7	8.0	DIP	120.0	18	0.12
P-58	70	J-51	J-52	8.0	DIP	120.0	2	0.01
P-59	75	J-53	J-51	8.0	DIP	120.0	20	0.13
P-60	72	J-53	J-54	8.0	DIP	120.0	2	0.01



**Southmoor Ridge**  
**FlexTable: Pipe Table**  
**Active Scenario: MDD**

Label	Length (Scaled) (ft)	Start Node	Stop Node	Diameter (in)	Material	Hazen-Williams C	Flow (gpm)	Velocity (ft/s)
P-61	142	J-4	J-55	8.0	DIP	120.0	23	0.15
P-62	78	J-55	J-53	8.0	DIP	120.0	21	0.14
P-63	72	J-55	J-56	8.0	DIP	120.0	2	0.01
P-64	42	H-2	J-57	8.0	DIP	120.0	0	0.00
P-65	42	J-57	J-58	8.0	DIP	120.0	2	0.01
P-66	66	J-57	J-59	8.0	DIP	120.0	-2	0.01
P-67	43	J-59	J-60	8.0	DIP	120.0	2	0.01
P-68	28	J-59	J-61	8.0	DIP	120.0	-3	0.02
P-69	61	J-61	J-8	8.0	DIP	120.0	-5	0.03
P-70	66	J-61	J-62	8.0	DIP	120.0	2	0.01
P-71	48	J-8	J-63	8.0	DIP	120.0	7	0.04
P-72	66	J-63	J-64	8.0	DIP	120.0	2	0.01
P-73	25	J-63	J-65	8.0	DIP	120.0	5	0.03
P-74	39	J-65	J-66	8.0	DIP	120.0	1	0.01
P-75	69	J-65	J-68	8.0	DIP	120.0	4	0.03
P-77	43	J-68	J-67	8.0	DIP	120.0	2	0.01
P-78	18	J-11	J-69	8.0	DIP	120.0	-32	0.21
P-79	106	J-69	J-13	8.0	DIP	120.0	-37	0.23
P-81	48	J-38	H-12	8.0	DIP	120.0	-35	0.22
P-82	31	H-12	J-6	8.0	DIP	120.0	-35	0.22
P-83	146	J-69	J-70	8.0	DIP	120.0	4	0.03
P-84	17	J-1	J-71	8.0	DIP	120.0	50	0.32
P-85	66	J-71	J-16	8.0	DIP	120.0	50	0.32
P-86	33	J-71	H-11	8.0	DIP	120.0	0	0.00
P-87	160	J-13	J-19	8.0	DIP	120.0	-37	0.23
P-88	175	J-3	J-24	8.0	DIP	120.0	33	0.21
P-89	56	J-30	J-28	8.0	DIP	120.0	26	0.17
P-90	38	J-68	J-72	8.0	DIP	120.0	2	0.02
P-91	14	J-72	H-1	8.0	DIP	120.0	0	0.00

**Southmoor Ridge**  
**FlexTable: Junction Table**  
**Active Scenario: MDD**

Label	Elevation (ft)	Demand (gpm)	Hydraulic Grade (ft)	Pressure (psi)
J-1	5,687.96	0	5,872.06	80
J-2	5,686.25	0	5,872.05	80
J-3	5,686.39	0	5,872.06	80
J-4	5,679.55	0	5,872.08	83
J-5	5,683.37	0	5,872.08	82
J-6	5,683.40	0	5,872.08	82
J-7	5,682.46	0	5,872.08	82
J-8	5,681.19	0	5,872.08	83
J-9	5,689.18	0	5,872.03	79
J-10	5,688.28	0	5,872.03	80
J-11	5,687.70	0	5,872.03	80
J-12	5,690.50	15	5,872.03	79
J-13	5,687.15	0	5,872.04	80
J-16	5,686.72	0	5,872.05	80
J-17	5,687.00	15	5,872.05	80
J-18	5,685.69	0	5,872.05	81
J-19	5,686.23	0	5,872.05	80
J-20	5,688.50	14	5,872.05	79
J-21	5,684.94	0	5,872.05	81
J-22	5,686.50	4	5,872.05	80
J-23	5,684.43	0	5,872.05	81
J-24	5,684.43	0	5,872.05	81
J-25	5,686.50	14	5,872.05	80
J-28	5,686.41	0	5,872.06	80
J-30	5,686.77	1	5,872.06	80
J-31	5,685.95	2	5,872.06	81
J-32	5,686.02	0	5,872.07	80
J-33	5,686.06	1	5,872.07	80
J-34	5,685.30	0	5,872.07	81
J-35	5,684.86	2	5,872.07	81
J-36	5,684.72	0	5,872.07	81
J-37	5,684.50	2	5,872.07	81
J-38	5,684.13	0	5,872.07	81
J-39	5,683.88	2	5,872.07	81
J-40	5,682.88	0	5,872.08	82
J-41	5,683.46	1	5,872.08	82
J-42	5,682.29	0	5,872.08	82
J-43	5,682.96	2	5,872.08	82
J-44	5,681.64	0	5,872.08	82
J-45	5,682.32	2	5,872.08	82
J-46	5,683.82	2	5,872.08	81
J-47	5,683.96	0	5,872.08	81
J-48	5,684.54	2	5,872.08	81
J-49	5,684.65	0	5,872.08	81
J-50	5,685.32	2	5,872.08	81
J-51	5,681.86	0	5,872.08	82
J-52	5,682.32	2	5,872.08	82
J-53	5,681.25	0	5,872.08	83
J-54	5,681.68	2	5,872.08	82
J-55	5,680.62	0	5,872.08	83
J-56	5,681.05	2	5,872.08	83
J-57	5,682.42	0	5,872.08	82
J-58	5,682.99	2	5,872.08	82

**Southmoor Ridge**  
**FlexTable: Junction Table**  
**Active Scenario: MDD**

Label	Elevation (ft)	Demand (gpm)	Hydraulic Grade (ft)	Pressure (psi)
J-59	5,681.92	0	5,872.08	82
J-60	5,682.38	2	5,872.08	82
J-61	5,681.68	0	5,872.08	82
J-62	5,681.38	2	5,872.08	83
J-63	5,681.23	0	5,872.08	83
J-64	5,680.77	2	5,872.08	83
J-65	5,681.25	0	5,872.08	83
J-66	5,681.50	1	5,872.08	82
J-67	5,680.91	2	5,872.08	83
J-68	5,680.71	0	5,872.08	83
J-69	5,687.70	0	5,872.04	80
J-70	5,688.70	4	5,872.04	79
J-71	5,687.70	0	5,872.06	80
J-72	5,680.40	2	5,872.08	83

**Southmoor Ridge**  
**Fire Flow Node FlexTable: Fire Flow Results Table**

**Active Scenario: Fire Flow**

Label	Satisfies Fire Flow Constraints?	Fire Flow Status	Fire Flow (Needed) (gpm)	Pressure (Residual Lower Limit) (psi)	Pressure (Calculated Residual) (psi)	Pressure (Calculated Zone Lower Limit) (psi)	Junction w/ Minimum Pressure (Zone)	Pressure (Calculated System Lower Limit) (psi)	Junction w/ Minimum Pressure (System)
H-1	True	Passed	2,000	20	47	49	J-72	49	J-72
H-2	True	Passed	2,000	20	46	50	J-58	50	J-58
H-3	True	Passed	2,000	20	67	70	J-9	70	J-9
H-4	True	Passed	2,000	20	66	69	J-10	69	J-10
H-5	True	Passed	2,000	20	69	70	J-13	70	J-13
H-7	True	Passed	2,000	20	71	72	J-18	72	J-18
H-8	True	Passed	2,000	20	70	70	J-25	70	J-25
H-10	True	Passed	2,000	20	72	73	J-28	73	J-28
H-11	True	Passed	2,000	20	72	75	J-71	75	J-71
H-12	True	Passed	2,000	20	75	75	J-38	75	J-38

**Southmoor Ridge**  
**FlexTable: Pipe Table**  
**Active Scenario: PHD**

Label	Length (Scaled) (ft)	Start Node	Stop Node	Diameter (in)	Material	Hazen-Williams C	Flow (gpm)	Velocity (ft/s)
P-1	98	J-1	R-2	8.0	DIP	120.0	-77	0.49
P-2	258	J-3	J-1	8.0	DIP	120.0	-14	0.09
P-3	81	J-4	R-4	8.0	DIP	120.0	-56	0.36
P-4	94	J-7	J-5	8.0	DIP	120.0	-19	0.12
P-5	136	J-6	J-7	8.0	DIP	120.0	-20	0.13
P-6	135	J-7	J-8	8.0	DIP	120.0	19	0.12
P-7	243	R-5	J-9	8.0	DIP	120.0	5	0.03
P-8	25	J-9	H-3	8.0	DIP	120.0	0	0.00
P-9	97	J-9	J-10	8.0	DIP	120.0	5	0.03
P-10	27	J-10	H-4	8.0	DIP	120.0	0	0.00
P-11	64	J-10	J-11	8.0	DIP	120.0	5	0.03
P-12	70	J-11	J-12	8.0	DIP	120.0	24	0.16
P-13	7	J-13	H-5	8.0	DIP	120.0	0	0.00
P-17	71	J-16	J-2	8.0	DIP	120.0	38	0.24
P-18	21	J-16	J-17	8.0	DIP	120.0	24	0.16
P-19	26	J-2	J-18	8.0	DIP	120.0	-11	0.07
P-20	9	J-18	H-7	8.0	DIP	120.0	0	0.00
P-22	23	J-19	J-2	8.0	DIP	120.0	-49	0.31
P-23	32	J-19	J-20	8.0	DIP	120.0	23	0.15
P-24	107	J-18	J-21	8.0	DIP	120.0	-11	0.07
P-25	56	J-21	J-22	8.0	DIP	120.0	7	0.05
P-26	97	J-21	J-23	8.0	DIP	120.0	-18	0.11
P-27	6	J-23	H-8	8.0	DIP	120.0	0	0.00
P-29	42	J-24	J-25	8.0	DIP	120.0	23	0.15
P-30	12	J-23	J-24	8.0	DIP	120.0	-18	0.11
P-32	23	J-3	J-28	8.0	DIP	120.0	-27	0.17
P-33	10	J-28	H-10	8.0	DIP	120.0	0	0.00
P-35	45	J-30	J-31	8.0	DIP	120.0	3	0.02
P-36	162	J-30	J-32	8.0	DIP	120.0	-31	0.20
P-37	43	J-32	J-33	8.0	DIP	120.0	2	0.01
P-38	62	J-32	J-34	8.0	DIP	120.0	-33	0.21
P-39	45	J-34	J-35	8.0	DIP	120.0	3	0.02
P-40	73	J-34	J-36	8.0	DIP	120.0	-35	0.23
P-41	44	J-36	J-37	8.0	DIP	120.0	3	0.02
P-42	73	J-36	J-38	8.0	DIP	120.0	-38	0.24
P-43	44	J-38	J-39	8.0	DIP	120.0	3	0.02
P-44	59	J-6	J-40	8.0	DIP	120.0	-21	0.13
P-45	43	J-40	J-41	8.0	DIP	120.0	2	0.01
P-46	66	J-40	J-42	8.0	DIP	120.0	-23	0.14
P-47	44	J-42	J-43	8.0	DIP	120.0	3	0.02
P-48	79	J-42	J-44	8.0	DIP	120.0	-25	0.16
P-49	232	J-44	J-4	8.0	DIP	120.0	-28	0.18
P-50	44	J-44	J-45	8.0	DIP	120.0	3	0.02
P-51	74	J-5	J-46	8.0	DIP	120.0	3	0.02
P-52	61	J-5	J-47	8.0	DIP	120.0	-22	0.14
P-53	73	J-47	J-48	8.0	DIP	120.0	3	0.02
P-54	67	J-47	J-49	8.0	DIP	120.0	-24	0.16
P-55	113	J-49	R-3	8.0	DIP	120.0	-27	0.17
P-56	71	J-49	J-50	8.0	DIP	120.0	3	0.02
P-57	73	J-51	J-7	8.0	DIP	120.0	20	0.13
P-58	70	J-51	J-52	8.0	DIP	120.0	3	0.02
P-59	75	J-53	J-51	8.0	DIP	120.0	23	0.15
P-60	72	J-53	J-54	8.0	DIP	120.0	3	0.02

**Southmoor Ridge**  
**FlexTable: Pipe Table**  
**Active Scenario: PHD**

Label	Length (Scaled) (ft)	Start Node	Stop Node	Diameter (in)	Material	Hazen-Williams C	Flow (gpm)	Velocity (ft/s)
P-61	142	J-4	J-55	8.0	DIP	120.0	28	0.18
P-62	78	J-55	J-53	8.0	DIP	120.0	25	0.16
P-63	72	J-55	J-56	8.0	DIP	120.0	3	0.02
P-64	42	H-2	J-57	8.0	DIP	120.0	0	0.00
P-65	42	J-57	J-58	8.0	DIP	120.0	3	0.02
P-66	66	J-57	J-59	8.0	DIP	120.0	-3	0.02
P-67	43	J-59	J-60	8.0	DIP	120.0	3	0.02
P-68	28	J-59	J-61	8.0	DIP	120.0	-5	0.03
P-69	61	J-61	J-8	8.0	DIP	120.0	-8	0.05
P-70	66	J-61	J-62	8.0	DIP	120.0	3	0.02
P-71	48	J-8	J-63	8.0	DIP	120.0	11	0.07
P-72	66	J-63	J-64	8.0	DIP	120.0	3	0.02
P-73	25	J-63	J-65	8.0	DIP	120.0	9	0.06
P-74	39	J-65	J-66	8.0	DIP	120.0	2	0.01
P-75	69	J-65	J-68	8.0	DIP	120.0	7	0.04
P-77	43	J-68	J-67	8.0	DIP	120.0	3	0.02
P-78	18	J-11	J-69	8.0	DIP	120.0	-19	0.12
P-79	106	J-69	J-13	8.0	DIP	120.0	-26	0.17
P-81	48	J-38	H-12	8.0	DIP	120.0	-41	0.26
P-82	31	H-12	J-6	8.0	DIP	120.0	-41	0.26
P-83	146	J-69	J-70	8.0	DIP	120.0	7	0.04
P-84	17	J-1	J-71	8.0	DIP	120.0	63	0.40
P-85	66	J-71	J-16	8.0	DIP	120.0	63	0.40
P-86	33	J-71	H-11	8.0	DIP	120.0	0	0.00
P-87	160	J-13	J-19	8.0	DIP	120.0	-26	0.17
P-88	175	J-3	J-24	8.0	DIP	120.0	41	0.26
P-89	56	J-30	J-28	8.0	DIP	120.0	27	0.17
P-90	38	J-68	J-72	8.0	DIP	120.0	4	0.03
P-91	14	J-72	H-1	8.0	DIP	120.0	0	0.00

**Southmoor Ridge**  
**FlexTable: Junction Table**  
**Active Scenario: PHD**

Label	Elevation (ft)	Demand (gpm)	Hydraulic Grade (ft)	Pressure (psi)
J-1	5,687.96	0	5,872.05	80
J-2	5,686.25	0	5,872.04	80
J-3	5,686.39	0	5,872.05	80
J-4	5,679.55	0	5,872.08	83
J-5	5,683.37	0	5,872.07	82
J-6	5,683.40	0	5,872.07	82
J-7	5,682.46	0	5,872.07	82
J-8	5,681.19	0	5,872.07	83
J-9	5,689.18	0	5,872.03	79
J-10	5,688.28	0	5,872.03	79
J-11	5,687.70	0	5,872.03	80
J-12	5,690.50	24	5,872.03	79
J-13	5,687.15	0	5,872.03	80
J-16	5,686.72	0	5,872.04	80
J-17	5,687.00	24	5,872.04	80
J-18	5,685.69	0	5,872.04	81
J-19	5,686.23	0	5,872.04	80
J-20	5,688.50	23	5,872.04	79
J-21	5,684.94	0	5,872.04	81
J-22	5,686.50	7	5,872.04	80
J-23	5,684.43	0	5,872.04	81
J-24	5,684.43	0	5,872.04	81
J-25	5,686.50	23	5,872.04	80
J-28	5,686.41	0	5,872.05	80
J-30	5,686.77	1	5,872.05	80
J-31	5,685.95	3	5,872.05	81
J-32	5,686.02	0	5,872.06	80
J-33	5,686.06	2	5,872.06	80
J-34	5,685.30	0	5,872.06	81
J-35	5,684.86	3	5,872.06	81
J-36	5,684.72	0	5,872.06	81
J-37	5,684.50	3	5,872.06	81
J-38	5,684.13	0	5,872.07	81
J-39	5,683.88	3	5,872.07	81
J-40	5,682.88	0	5,872.07	82
J-41	5,683.46	2	5,872.07	82
J-42	5,682.29	0	5,872.07	82
J-43	5,682.96	3	5,872.07	82
J-44	5,681.64	0	5,872.08	82
J-45	5,682.32	3	5,872.08	82
J-46	5,683.82	3	5,872.07	81
J-47	5,683.96	0	5,872.08	81
J-48	5,684.54	3	5,872.08	81
J-49	5,684.65	0	5,872.08	81
J-50	5,685.32	3	5,872.08	81
J-51	5,681.86	0	5,872.07	82
J-52	5,682.32	3	5,872.07	82
J-53	5,681.25	0	5,872.08	83
J-54	5,681.68	3	5,872.08	82
J-55	5,680.62	0	5,872.08	83
J-56	5,681.05	3	5,872.08	83
J-57	5,682.42	0	5,872.07	82
J-58	5,682.99	3	5,872.07	82

**Southmoor Ridge**  
**FlexTable: Junction Table**  
**Active Scenario: PHD**

Label	Elevation (ft)	Demand (gpm)	Hydraulic Grade (ft)	Pressure (psi)
J-59	5,681.92	0	5,872.07	82
J-60	5,682.38	3	5,872.07	82
J-61	5,681.68	0	5,872.07	82
J-62	5,681.38	3	5,872.07	83
J-63	5,681.23	0	5,872.07	83
J-64	5,680.77	3	5,872.07	83
J-65	5,681.25	0	5,872.07	83
J-66	5,681.50	2	5,872.07	82
J-67	5,680.91	3	5,872.07	83
J-68	5,680.71	0	5,872.07	83
J-69	5,687.70	0	5,872.03	80
J-70	5,688.70	7	5,872.03	79
J-71	5,687.70	0	5,872.05	80
J-72	5,680.40	4	5,872.07	83



APPENDIX D  
WASTEWATER FLOWS



**SANITARY SEWER DEMAND CALCULATIONS**

Project #: 2303146  
 Project: Southmoor Ridge

Location: Fountain, Colorado  
 Plan Date: \_\_\_\_\_

By C Budge  
 Checked \_\_\_\_\_

Date 2/15/2024  
 Date \_\_\_\_\_

Design Point	Location	Land Use	Area (sq-ft)	Residential					Commercial (Office / Small Business / Restaurant)					Totals						Pipe Parameters													
				Units	Single Family Equivalent (SFE)	Average Day Flow (gpm)	Average Day Flow (mgd)	Average Day Flow (cfs)	Units	Single Family Equivalent (SFE)	Average Day Flow (gpm)	Average Day Flow (mgd)	Average Day Flow (cfs)	Peaking Factor	Peak Flow (gpm)	Infiltration / Inflow (gpm)	Peak Flow + I/I (gpm)	Peak Flow + I/I (mgd)	Peak Flow + I/I (cfs)	Total SFE	Upstream Manhole ID	Downstream Manhole ID	Pipe Slope (%)	Pipe Size (in)	Full Pipe flow (gpm)	Maximum Capacity 75% full (gpm)	Ratio PDF/ 75% Capacity						
1	Apartments	Studio/1-2 Bed		202	64	19.8	0.03	0.04							5.0	98.8	2.0	<b>100.8</b>	0.145	0.225													
	Apartments	3 Bed		8	4	1.1	0.002	0.003							5.0	5.7	0.1	<b>5.8</b>	0.008	0.013													
	Amenity	Pool	1,500						1	0.2	0.1	0.001	0.0001		5.0	0.3	0.0	<b>0.3</b>	0.000	0.001													
	Amenity	Clubhouse	4,250						1	5.3	1.5	0.002	0.003		5.0	7.4	0.1	<b>7.5</b>	0.011	0.017													
	Total at Design Point				210	67	21	0.030	0.047	2	5.5	1.5	0.003	0.003		5.0	112.2	2.2	<b>114.5</b>	0.165	0.255	73.01	-	-	1.0	8	542.34	494.6	23.1%				
2	Townhomes	1-Bed		9	2.8	0.9	0.001	0.002							5.0	4.4	0.1	<b>4.5</b>	0.006	0.010													
	Townhomes	2-3 Bed		68	21.5	9.7	0.014	0.022							5.0	48.6	1.0	<b>49.6</b>	0.071	0.110													
	Total at Design Point				77	24	11	0.015	0.024	0	0	0	0	0		5.0	53.0	1.1	<b>54.1</b>	0.078	0.120	24.3	-	-	1.0	8	542.34	494.6	10.9%				

APPENDIX E  
WASTEWATER HYDRAULIC MODELING

## Worksheet for 8-in Pipe - 75% Capacity

### Project Description

Friction Method	Manning Formula
Solve For	Discharge

### Input Data

Roughness Coefficient	0.013	
Channel Slope	0.01000	ft/ft
Normal Depth	6.00	in
Diameter	8.00	in

### Results

Discharge	494.55	gal/min
Flow Area	0.28	ft <sup>2</sup>
Wetted Perimeter	1.40	ft
Hydraulic Radius	2.41	in
Top Width	0.58	ft
Critical Depth	0.50	ft
Percent Full	75.0	%
Critical Slope	0.01010	ft/ft
Velocity	3.92	ft/s
Velocity Head	0.24	ft
Specific Energy	0.74	ft
Froude Number	0.99	
Maximum Discharge	583.40	gal/min
Discharge Full	542.34	gal/min
Slope Full	0.00832	ft/ft
Flow Type	SubCritical	

### GVF Input Data

Downstream Depth	0.00	in
Length	0.00	ft
Number Of Steps	0	

### GVF Output Data

Upstream Depth	0.00	in
Profile Description		
Profile Headloss	0.00	ft
Average End Depth Over Rise	0.00	%
Normal Depth Over Rise	75.00	%
Downstream Velocity	Infinity	ft/s

---

## Worksheet for 8-in Pipe - 75% Capacity

---

### GVF Output Data

Upstream Velocity	Infinity	ft/s
Normal Depth	6.00	in
Critical Depth	0.50	ft
Channel Slope	0.01000	ft/ft
Critical Slope	0.01010	ft/ft

# APPENDIX F

## MAPS

# SOUTHMOOR RIDGE

## VICINITY MAP

A TRACT OF LAND LOCATED IN A PORTION OF THE NORTH HALF OF THE NORTHWEST QUARTER OF SECTION 24, AND IN A PORTION OF THE SOUTH HALF OF THE SOUTHWEST QUARTER OF SECTION 13, ALL IN TOWNSHIP 15 SOUTH, RANGE 66 WEST OF THE 6TH P.M., COUNTY OF EL PASO, STATE OF COLORADO



VICINITY MAP  
SCALE: 1"=1,000'

LYON, RICHELIE, 2/12/2024, 2:12 PM

HR GREEN - Xref: xc-dgn; xgt-1-d01\_24x36; xc-uti; xv-row-3146; xc-row; xv-dgn-3146; rony\_tpcals; xv-uti-3146; Legend\_ODP; Vicinity\_Map

DRAWN BY: DLH      JOB DATE: 2/12/2024  
 APPROVED: RDL      JOB NUMBER: 2303146  
 CAD DATE: 1/5/2024  
 CAD FILE: J:\2023\2303146\CAD\Drawings\Civility\_Map\Vicinity-Map\_2303146

BAR IS ONE INCH ON OFFICIAL DRAWINGS.  
 0 1" IF NOT ONE INCH, ADJUST SCALE ACCORDINGLY.

NO.	DATE	BY	REVISION DESCRIPTION



HR GREEN - COLORADO SPRINGS  
 7222 COMMERCE CENTER DR. SUITE 220  
 COLORADO SPRINGS CO 80919  
 PHONE: 719.622.6222  
 FAX: 844.273.1057

SOUTHMOOR RIDGE  
 DHN DEVELOPMENT INC.  
 FOUNTAIN, COLORADO



CONCEPT PLAN & OVERALL DEVELOPMENT PLAN  
 VICINITY MAP






# SOUTHMOOR RIDGE

## PRELIMINARY UTILITY PLANS


A TRACT OF LAND LOCATED IN A PORTION OF THE NORTH HALF OF THE NORTHWEST QUARTER OF SECTION 24, AND IN A PORTION OF THE SOUTH HALF OF THE SOUTHWEST QUARTER OF SECTION 13, ALL IN TOWNSHIP 15 SOUTH, RANGE 66 WEST OF THE 6TH P.M., COUNTY OF EL PASO, STATE OF COLORADO




VICINITY MAP (SCALE: 1"=1,000')

### LEGEND

	EXISTING	PROPOSED		EXISTING	PROPOSED
MATCH LINE	---	---	STORM SEWER		
LOT LINE	---	---	MANHOLE	⊙	⊙
SECTION LINE	---	---	STORM INLET	⊙	⊙
PROPERTY LINE	---	---	FLARED END SECTION	⊙	⊙
EASEMENT LINE	---	---	RIPRAP	⊙	⊙
RIGHT OF WAY	---	---	CONC. FOREBAY	⊙	⊙
CENTERLINE	---	---	CONC. TRICKLE CHANNEL	⊙	⊙
PLASTIC FENCE	X-X	X-X	DETENTION AREA	⊙	⊙
WOODEN FENCE			SANITARY SEWER		
U.G. ELECTRIC	UE	UE	CLEAN OUT	⊙	⊙
OVERHEAD ELECTRIC	OHE	OHE	MANHOLE	⊙	⊙
GAS MAIN	UG	UG	PLUG	⊙	⊙
SANITARY SEWER	---	---	WATER		
STORM DRAIN	---	---	FIRE HYDRANT	⊙	⊙
TELEPHONE	UT	UT	FIRE DEPT. CONNECTION	⊙	⊙
WATER MAIN	---	---	GATE VALVE	⊙	⊙
SWALE	---	---	MANHOLE	⊙	⊙
TRAIL	---	---	METER	⊙	⊙
CURB & GUTTER	---	---	TEE	⊙	⊙
INDEX CONTOUR	---5250---	---5250---	REDUCER	⊙	⊙
INTER. CONTOUR	---	---			
100-YR FLOODPLAIN	---	---			
FLOODWAY	---	---			
			DRY UTILITIES		MISCELLANEOUS
			ELECTRIC METER	⊙	SIGN
			ELECTRIC PEDESTAL	⊙	BOLLARD
			ELECTRICAL CABINET	⊙	ACCESSIBLE PARKING
			ELECTRIC VAULT	⊙	
			FIBER OPTIC PULL BOX	⊙	
			FIBER OPTIC MANHOLE	⊙	
			FIBER OPTIC PEDESTAL	⊙	
			FIBER OPTIC SIGN	⊙	
			FIBER OPTIC VAULT	⊙	
			GAS METER	⊙	
			GAS SIGN	⊙	
			GAS VAULT	⊙	
			TELEPHONE CABINET	⊙	
			TELEPHONE MANHOLE	⊙	
			TELEPHONE SIGNAL/MAST	⊙	
			TELEPHONE SIGN	⊙	
			TELEPHONE PEDESTAL	⊙	
			TRANSFORMER	⊙	
			LIGHT POLE	⊙	
			FIBER OPTIC VAULT	⊙	



- NOTES:**
1. WATER AND WASTEWATER SERVICES TO BE PROVIDED BY SECURITY WATER & SANITATION DISTRICT AND NATURAL GAS SERVICES BY AGUIA AND COLORADO SPRINGS UTILITIES. ELECTRIC SERVICE WILL BE BY CITY OF FOUNTAIN. INTERNET AND TV WILL BE BY LOCAL PROVIDERS.
  2. EXISTING LOT SCH. NO. 6524200052 REQUIRES A PETITION FOR INCLUSION FOR WASTEWATER INTO THE SECURITY WASTEWATER DISTRICT. EXISTING LOT NO. 6524200053 REQUIRES A PETITION FOR INCLUSION FOR WATER AND WASTEWATER INTO THE SECURITY WATER DISTRICT AND THE SECURITY WASTEWATER DISTRICT. PETITION OF INCLUSION HAVE BEEN SUBMITTED TO SECURITY WATER AND SANITATION DISTRICT.
  3. ALL PROPOSED PUBLIC AND PRIVATE WATER AND WASTEWATER MAIN ARE DESIGNED TO MEET SECURITY WATER & SANITATION DISTRICT CONSTRUCTION STANDARDS INCLUDING HORIZONTAL SEPARATIONS OF A MINIMUM OF 10.0' FROM PIPE EDGE TO EDGE BETWEEN WATER AND WASTEWATER.
  4. HYDRANTS ARE SITED AT A MINIMUM OF 500' SPACING FROM DWELLING UNITS AND AMENITY BUILDINGS. NUMBER OF HYDRANTS REQUIRED FOR THE APARTMENT BUILDINGS AND AMENITY BUILDINGS ARE DETERMINED BY CITY OF FOUNTAIN FIRE PROTECTION DISTRICT AND I.F.C. CRITERIA FOR THEIR CONSTRUCTION TYPES. HYDRANTS ARE SITED FOR A MINIMUM OF TWO (2) HYDRANTS WITHIN HOSE LAY DISTANCE OF APARTMENT AND AMENITY BUILDINGS.
  5. APARTMENT BUILDINGS ARE SPRINKLERED AND HAVE RISER PIPES FOR INTERNAL FIRE DEPARTMENT CONNECTIONS WITHIN STAIRWELLS ON EACH SIDE OF THE BUILDING.
  6. FIRE DEPARTMENT CONNECTIONS ARE AT THE FIRE SERVICE LINE ENTRY LOCATIONS AND ARE WITHIN 100' OF A HYDRANT.
  7. INDIVIDUAL TOWNHOME UNITS ARE SERVICED INDIVIDUALLY WITH A PRIVATE WATER AND WASTEWATER SERVICE TAP TO PUBLIC MAIN AS SHOWN ON THE PLAN. TAP SEPARATIONS ARE AT A MINIMUM OF 5.0'.



LYON, RICHIE, 2/14/2024, 10:04 AM

DRAWN BY: DLH	JOB DATE: 2/12/2024	BAR IS ONE INCH ON OFFICIAL DRAWINGS.
APPROVED: RDL	JOB NUMBER: 2303146	0" = 1"
CAD DATE: 2/14/2024		IF NOT ONE INCH, ADJUST SCALE ACCORDINGLY.
CAD FILE: J:\2023\2303146\CAD\DWG\C\Prelim_Uilities\Preliminary_Uilities-3146		

NO.	DATE	BY	REVISION DESCRIPTION

**HRGreen**  
 HR GREEN - COLORADO SPRINGS  
 7222 COMMERCE CENTER DR. SUITE 220  
 COLORADO SPRINGS CO 80919  
 PHONE: 719.622.6222  
 FAX: 844.273.1057

**SOUTHMOOR RIDGE**  
 DHN DEVELOPMENT INC.  
 FOUNTAIN, COLORADO

**DHN Development**

**PLACES management**

OVERALL DEVELOPMENT PLAN  
 PRELIMINARY UTILITY PLAN

SHEET UTIL 2

# APPENDIX F

## REFERENCES



	HGL	Static Pressure (psi)	Fire Flow (gpm)		Flow (gpm)	Residual Pressure (psi)
H-46	5872.09	81	3,500		1,000	60
H-47	5872.08	79	3,500			58
H-48	5872.07	78	3,500		1,000	56
H-49	5872.05	80	3,134			60
H-50	5872.03	80	3,500			60
H-51	5872.03	76	3,500			56

# Security Water and Sanitation Districts / Enterprises

231 SECURITY BLVD. • COLORADO SPRINGS, COLORADO 80911  
TELEPHONE 719-392-3475 • FAX 719-390-7252  
www.securitywsd.com

## Memorandum

To: Bryan Kniep, DHN Development

From: Brandon Bernard, Operations Manager

Re: Southmoor Development – TENTATIVE New Construction Fees

Per the developer's request, I have configured what the New Construction Fees could look like, based on the information provided, for the Southmoor development located at the intersection of Southmoor Drive and the future Fountain Blvd.

### 1. Irrigation Supply

This irrigation supply is conceptual in nature as no landscape plan was provided for the Southmoor Development.

Southmoor Development - Landscape Plan - Tentative				
Type	Amount	GPH	Hours	Total Gallons
Deciduous Tree	31	4	52	6448
Deciduous Shrubs	62	2	52	6448
Evergreen Trees	21	4	26	2184
Evergreen Shrubs	60	2	26	3120
Kentucky Bluegrass	1 acre x 325,851 gallons per AF			325,851
		Total gallons		344,051
344,051 gallons / 325,851 gallons per AF = 1.06 Annual Acre Feet				
1.06 AAF x \$43,797.00 per AAF* = <b>\$46,424.82</b>				

\*Based on Harvey Economics Consultants

## 2. Domestic Supply

Water Development Fees are established by water service fixture units (WSFU's). Based on the information provided, it has been determined that this development could have:

- 60 studio apartments with 7.8 WSFU's = 468 WSFU's
- 72 one-bedroom apartments with 7.8 WSFU's = 561.8 WSFU's
- 79 two- or three-bedroom townhouses with 11.4 WSFU's = 900.6 WSFU's
- 39 two-bedroom apartments with 7.8 WSFU's = 304.2 WSFU's
- 39 two-bedroom apartments with 11.4 WSFU's = 444.6 WSFU's

In total, this development will have 2,679 WSFU's. It has been determined by the District that a single family equivalent (SFE) is equal to 24.7 WSFU's.

- $2,679 \text{ WSFU's} / 24.7 = 108.46 \text{ SFE's}$
- $108.46 \text{ SFE's} \times 0.5 \text{ annual acre feet (AAF) per SFE} = 54.23 \text{ AAF}$
- $54.23 \text{ AAF} \times 5\% \text{ of domestic consumptive use} = 2.71 \text{ AAF of consumptive use}$
- $2.71 \text{ AAF} \times \$36,328.00 \text{ per AAF} = \$98,448.88$
- $108.46 \text{ AAF} \times \$7,469.00 \text{ of the Major Infrastructure Component} = \$810,087.74$

Tentative Total Domestic Water Development Fee = \$908,536.62

## 3. Swimming Pool

The size of the pool for this development is unknown, so the water development fees are based on an assumed 1,500 sq ft pool. Tentative and preliminary considerations for a water development fee for this swimming pool are in direct relation to the added consumptive use created by this project. There will be additional consumptive use created as well due to evaporation from the free water surface existing at this facility. We have considered the following factors:

The free surface is represented by the plan area of the pool being 1500 sqft.

We have estimated the evaporation from this free water surface using representative NOAA evaporation pan data from the following NOAA/WSO stations, averaging 30 years of data.

- Pueblo Weather Service Office (WSO) at the airport
- Pueblo City Reservoir
- Pueblo Reservoir

Adjusting the pan evaporation for the expected period of use, May 1 to October 15, and utilizing a pan coefficient of 0.7, it is determined that the expected evaporation from the free water surface will range from 3.06 feet to 3.22 feet. Utilizing arithmetic mean of the evaporation data of record, we suggest that the expected average annual consumptive use from the free water surface will be 3.16 feet or 3.16 annual acre feet (AAF) per acre of surface water.

- A. Based on the pool area of 1500 square feet and the expected evaporation on an average annual basis, the consumptive use is estimated at 0.107 annual acre-feet (AAF)
- B. The Security Water District's adopted policy recognizes a water development fee for non-residential use at the rate of \$43,797.00 per AAF of consumptive use. The estimated water development fee for this pool project is as follows.

$$\text{WDF} = \$43,797.00 / \text{AAF} \times 0.107 \text{ AAF} = \$4,686.28$$

$$\text{Tentative Total Domestic Water Development Fee} = \$421,120.34$$

---

### **Table of Total Fees**

1. 3/4-inch water tap = \$6,000.00 x 79 = \$474,000.00
2. 3/4-inch water meter = \$332.68 x 79 = \$26,281.72
3. 1-inch water tap = \$7,500.00 x 2 (Pool and Clubhouse) = \$15,000.00
4. 2-inch irrigation water meter = \$1,423.33
5. 3-inch water tap = \$24,690.00 x 4 = \$98,760.00
6. 3-inch water meter = \$2,727.00 x 4 = \$10,908.00
7. Water Development Fee (Irrigation + Domestic + Pool) = \$1,376,081.78
8. Residential Inspection Fee = \$31.00 x 86 = \$2,666.00
9. Townhome Sewer Tap = \$7,551.00 x 79 = \$596,529.00
10. Clubhouse Sewer Tap = \$7,551.00
11. Pool house Sewer Tap = \$7,551.00
12. Apartments Sewer Tap = \$7,551.00 x 4 = \$30,204.00
13. One- and Two-Bedroom Fixtures Over 18 = 1968 x \$213.00 = \$419,184.00
14. Residential Inspection Fee = \$31.00 x 85 = \$2,635.00

After reviewing the limited information that has been provided so far for this project, we have determined that Security Water and Sanitation Districts currently have overall capacities sufficient to provide services to the subject property. This determination is based on the scant information provided to us up to this point, and any significant changes to the plan would require further evaluation to see if a modification of our determination is warranted.

Furthermore, this determination should not be considered as a service commitment. No commitment can be provided until the property owner completes the process to include the property into the Security Water District and the Security Sanitation District. No water resources

or wastewater treatment capacity would be committed to the property until an application for final plat is submitted to the appropriate jurisdiction. Any service commitment may also be subject to determinations of sufficiency and reliability of water supply by El Paso County and the Colorado Division of Water Resources. Water and sewer service would be subject to the rules, regulations, and conditions of the districts and the payment of appropriate fees at the time of requested connection. The current fee schedule is posted on the district's website, [Securitywsd.com](http://Securitywsd.com).