

Prevent • Promote • Protect

Environmental Health Division 1675 W. Garden of the Gods Road Suite 2044 Colorado Springs, CO 80907 (719) 578-3199 phone (719) 578-3188 fax

www.elpasocountyhealth.org

Pike Solar 1041, AASI-21-2

Please accept the following comments from El Paso County Public Health regarding the 1,170-acre solar energy facility project referenced above:

- El Paso County Public Health understands the project will not require
 wastewater services after the construction of the facility has been
 completed. Portable sanitary facilities are for temporary use only and
 must be removed when the construction phase is completed.
- El Paso County Public Health also understands Colorado Springs will supply water service for the project. Water will be used for dust control during construction of the facility as required for permit compliance.
- Earthmoving activities greater than 25 acres require a Construction Activity Permit from the Colorado Department of Public Health and Environment, Air Pollution Control Division. Please contact the Air Pollution Control Division at for permit information https://www.colorado.gov/pacific/cdphe/air-permits-contacts
- The water quality basins must have mosquito control responsibilities included as a part of the construction design and maintenance plan to help control mosquito breeding habitat and minimize the potential for West Nile Virus.

Mike McCarthy
El Paso County Public Health
719.575.8602
mikemccarthy@elpasoco.com
22Apr2021