



Prevent • Promote • Protect

Environmental Health Division
1675 W. Garden of the Gods Road
Suite 2044
Colorado Springs, CO 80907
(719) 578-3199 *phone*
(719) 578-3188 *fax*
www.elpasocountyhealth.org

Reimers, PPR-19-041

Please accept the following comments from El Paso County Public Health for the project referenced above:

- The permitted and approved onsite wastewater treatment system (OWTS) was installed in 2004 and sized for a 4-bedroom house. The soil treatment area (STA) is located southwest of the house. Do not use this area for any parking, roads or storage that could cause compaction to the soil treatment areas. A map of the OWTS components is available on the El Paso County Assessor's Office website.
- There will likely be a restroom planned for the proposed future shop. The OWTS for the shop will require full compliance with the OWTS Regulations. The Letter of Intent mentioned the necessity to comply with all codes.

Mike McCarthy
El Paso County Public Health
Environmental Health Division
719.575.8602
mikemccarthy@elpasoco.com
17Nov2019