



ENTECH
 ENGINEERING, INC.
 505 Elkton Drive
 Colorado Springs, CO 80907
 (719) 531-5599 • (719) 531-5238 (fax)

Client: **FLRD #5**
 Project: **Forest Lakes Residential Development, Filing 5**
 Entech Job # **192273**

CONCRETE TEST

EO			Test #:			17		
Date:	# of Specimens	Specified Strength (psi)	Time of Test	Hours Field Cured	Lab Receive Date:			
8/14/2020	4	4500	1:35 PM	24	8/15/2020			
Specimen Type			Test Type			Type of Cure		
Cylinders 4x8			Field			Tank		
Contractor:			Supplier:			Mix Design Number		
PPC Construction			Pete Lien			90DJ50		
Truck Number			Ticket Number			Batch Time:		
997			974434			12:15 PM		

Location:
 Trickle channel, 10' northeast and 5' northwest of southwest corner of pond, southwest side of Pond C.

Slump (in.):	Air (%):	Unit Weight (PCF):	Concrete Temp (°F)	Air Temp (°F)
2.5	6.9	143.1	87	90

7-Day Strength	28-Day Strength	-Day Strength	56-Day Strength	-Day Strength
4390	5360			
	5510			
Average:	Average:	Average:	Average:	Average:
4390	5440			
Break Date:	Break Date:	Break Date:	Break Date:	Break Date:
8/21/2020	9/11/2020			

Remarks:
28 Day Results

Specifications: 4500 PSI, 4" Max Slump, 4.5-7.5% Air	Break Sequence: 1 @ 7, 2 @ 28, 1 @ hold
Summary Comments: PPC Construction, Pete Lien	

Reviewed By: *RPJ*

