



**ENTECH**  
 ENGINEERING, INC.  
 505 Elkton Drive  
 Colorado Springs, CO 80907  
 (719) 531-5599 • (719) 531-5238 (fax)

Client:	FLRD #5
Project:	Forest Lakes Residential Development, Filing 5
Entech Job #	192273

**CONCRETE TEST**

<b>EO</b>			Test #:	<b>16</b>		
Date:	# of Specimens	Specified Strength (psi)	Time of Test	Hours Field Cured	Lab Receive Date:	
8/14/2020	4	4500	10:15 AM	24	8/15/2020	

<i>Specimen Type</i>	<i>Test Type</i>	<i>Type of Cure</i>
----------------------	------------------	---------------------

<b>Cylinders 4x8</b>	<b>Field</b>	<b>Tank</b>
----------------------	--------------	-------------

Contractor:	Supplier:	Mix Design Number
PPC Construction	Pete Lien	90DJ50

Truck Number	Ticket Number	Batch Time:
311	974419	9:27 AM

Location:  
 Trickle channel, 5' northeast and 3' northwest of southwest corner of pond, southwest side of Pond C.

Slump (in.):	Air (%):	Unit Weight (PCF):	Concrete Temp (°F)	Air Temp (°F)
3.0	7.2	138.9	83	92

7-Day Strength	28-Day Strength	-Day Strength	56-Day Strength	-Day Strength
3800	5080			
	4900			
Average:	Average:	Average:	Average:	Average:
3800	4990			
Break Date:	Break Date:	Break Date:	Break Date:	Break Date:
8/21/2020	9/11/2020			

Remarks:  
**28 Day Results**

Specifications:	Break Sequence:
4500 PSI, 4" Max Slump, 5-8% Air	1@7, 2@28, 1@hold
Summary Comments:	
PPC Construction, Pete Lien	

Reviewed By: *R.P.J.*

