



ENTECH
 ENGINEERING, INC.
 505 Elkton Drive
 Colorado Springs, CO 80907
 (719) 531-5599 • (719) 531-5238 (fax)

Client: **FLRD #2**
 Project: **Forest Lakes Residential Development, Filing 5**
 Entech Job # **192273**

CONCRETE TEST

TG			Test #: 19		
Date: 8/18/2020	# of Specimens: 4	Specified Strength (psi): 4500	Time of Test: 1:15 PM	Hours Field Cured: 24	Lab Receive Date: 8/19/2020

Specimen Type	Test Type	Type of Cure
Cylinders 4x8	Field	Tank

Contractor: PPC Construction	Supplier: Pete Lien	Mix Design Number: 90DJ50
-------------------------------------	----------------------------	----------------------------------

Truck Number: 2277	Ticket Number: 974586	Batch Time: 12:12 PM
---------------------------	------------------------------	-----------------------------

Location:
Inlet walls (south side), Lot 30/31.

Slump (in.): 4.0	Air (%): 7.2	Unit Weight (PCF):	Concrete Temp (°F): 86	Air Temp (°F): 90
-------------------------	---------------------	--------------------	-------------------------------	--------------------------

<i>7-Day Strength</i>	<i>28-Day Strength</i>	<i>-Day Strength</i>	<i>56-Day Strength</i>	<i>-Day Strength</i>
3240				
Average: 3240	Average:	Average:	Average:	Average:
Break Date: 8/25/2020	Break Date: 9/15/2020	Break Date:	Break Date:	Break Date:

Remarks:
7 Day Results

Specifications: 4500 PSI, 4" Max Slump, 4.5-7.5% Air	Break Sequence: 1@7, 2@28, 1@hold
---	--------------------------------------

Summary Comments:
PPC Construction, Pete Lien

Reviewed By: *RPJ*