



ENTECH
 ENGINEERING, INC.
 505 Elkton Drive
 Colorado Springs, CO 80907
 (719) 531-5599 • (719) 531-5238 (fax)

Client:	FLRD #2
Project:	Forest Lakes Residential Development, Filing 5
Entech Job #	192273

CONCRETE TEST

PG			Test #:			3		
Date:	# of Specimens	Specified Strength (psi)	Time of Test	Hours Field Cured	Lab Receive Date:			
7/20/2020	4	4000	1:30 PM	24	7/21/2020			
Specimen Type		Test Type			Type of Cure			
Cylinders 4x8		Field			Tank			
Contractor:		Supplier:		Mix Design Number				
PPC Construction		Pete Lien		90DJ50				
Truck Number		Ticket Number		Batch Time:				
2270		973007		12:06 PM				

Location:
 Slab for inlet, northeast corner of property line 400' from highest point of development.

Slump (in.):	Air (%):	Unit Weight (PCF):	Concrete Temp (°F)	Air Temp (°F)
4	6.4		85	83
7-Day Strength	28-Day Strength	-Day Strength	56-Day Strength	-Day Strength
3770	5050			
	5360			
Average:	Average:	Average:	Average:	Average:
3770	5240			
Break Date:	Break Date:	Break Date:	Break Date:	Break Date:
7/27/2020	8/17/2020			

Remarks:
 28 Day Results

Specifications:	Break Sequence:
4000 PSI, 4" Max Slump, 5-8% Air	1@7, 2@28, 1@hold
Summary Comments:	
PPC Construction, Pete Lien	

Reviewed By:

