



ENTECH
 ENGINEERING, INC.
 505 Elkton Drive
 Colorado Springs, CO 80907
 (719) 531-5599 • (719) 531-5238 (fax)

Client:	FLRD #5
Project:	Forest Lakes Residential Development, Filing 5
Entech Job #	192273

CONCRETE TEST

PG			Test #: 23		
Date:	# of Specimens	Specified Strength (psi)	Time of Test	Hours Field Cured	Lab Receive Date:
8/26/2020	4	4500	1:10 PM	24	8/27/2020
Specimen Type		Test Type		Type of Cure	
Cylinders 4x8		Field		Tank	
Contractor:		Supplier:		Mix Design Number	
PPC Construction		Pete Lien		90DJ50	
Truck Number		Ticket Number		Batch Time:	
2277		975081		12:02 PM	

Location:
 Lids for outlets, Lots 9 & 10 (north lid).

Slump (in.):	Air (%):	Unit Weight (PCF):	Concrete Temp (°F)	Air Temp (°F)
4.0	6.1	139.0	85	85

7-Day Strength	28-Day Strength	-Day Strength	56-Day Strength	-Day Strength
4520				
Average:	Average:	Average:	Average:	Average:
4520				
Break Date:	Break Date:	Break Date:	Break Date:	Break Date:
9/2/2020	9/23/2020			

Remarks:
7 Day Results

Specifications: 4500 PSI, 4" Max Slump, 4.5-7.5% Air	Break Sequence: 1@7, 2@28, 1@hold
Summary Comments: PPC Construction, Pete Lien	

Reviewed By: *RJ*