



ENTECH
 ENGINEERING, INC.
 505 Elkton Drive
 Colorado Springs, CO 80907
 (719) 531-5599 • (719) 531-5238 (fax)

Client:	FLRD #5
Project:	Forest Lakes Residential Development, Filing 5
Entech Job #	192273

CONCRETE TEST

PG			Test #: 20		
Date: 8/19/2020	# of Specimens: 4	Specified Strength (psi): 4500	Time of Test: 1:47 PM	Hours Field Cured: 24	Lab Receive Date: 8/20/2020
Specimen Type		Test Type		Type of Cure	
Cylinders 4x8		Field		Tank	
Contractor: PPC Construction		Supplier: Pete Lien		Mix Design Number: 90DJ50	
Truck Number: 312		Ticket Number: 974670		Batch Time: 1:03 PM	

Location:
 Inlet walls, 150' north and 200' west of center of cul-de-sac on Timber Trek Way.

Slump (in.): 3.75	Air (%): 6.0	Unit Weight (PCF): 138.6	Concrete Temp (°F): 85	Air Temp (°F): 87
7-Day Strength	28-Day Strength	-Day Strength	56-Day Strength	-Day Strength
3250				
Average: 3250	Average:	Average:	Average:	Average:
Break Date: 8/26/2020	Break Date: 9/16/2020	Break Date:	Break Date:	Break Date:

Remarks:
7 Day Results

Specifications: 4500 PSI, 4" Max Slump, 4.5-7.5% Air	Break Sequence: 1@7, 2@28, 1@hold
---	--------------------------------------

Summary Comments:
 PPC Construction, Pete Lien

Reviewed By: *RPJ*