



ENTECH
 ENGINEERING, INC.
 505 Elkton Drive
 Colorado Springs, CO 80907
 (719) 531-5599 • (719) 531-5238 (fax)

Client:	FLRD #2
Project:	Forest Lakes Residential Development, Filing 5
Entech Job #	192273

CONCRETE TEST

EO			Test #:	10		
Date:	# of Specimens	Specified Strength (psi)	Time of Test	Hours Field Cured	Lab Receive Date:	
8/5/2020	4	4500	1:05 PM	24	8/6/2020	
Specimen Type		Test Type		Type of Cure		
Cylinders 4x8		Field		Tank		
Contractor:		Supplier:		Mix Design Number		
PPC Construction		Pete Lien		90DJ50		
Truck Number		Ticket Number		Batch Time:		
312		973932		12:02 PM		

Location
 (Outlet Drain Pad) 6' west and 5' south off northeast corner of outlet drain into Pond C.

Slump (in.)	Air (%):	Unit Weight (PCF):	Concrete Temp (°F)	Air Temp (°F)
3.75	5.2	140.8	84	79
7-Day Strength	28-Day Strength	-Day Strength	56-Day Strength	-Day Strength
4470				
Average:	Average:	Average:	Average:	Average:
4470				
Break Date:	Break Date:	Break Date:	Break Date:	Break Date:
8/12/2020	9/2/2020			

Remarks:
 7 day results

Specifications: 4500 PSI, 4" Max Slump, 4.5-7.5% Air	Break Sequence: 1@7, 2@28, 1@hold
---	--------------------------------------

Summary Comments:
 PPC Construction, Pete Lien

Reviewed By: *RPJ*