



**ENTECH**  
 ENGINEERING, INC.  
 505 Elkton Drive  
 Colorado Springs, CO 80907  
 (719) 531-5599 • (719) 531-5238 (fax)

|              |  |
|--------------|--|
| Client:      | FLRD #2  |
| Project:     | Forest Lakes Residential Development, Filing 5 |
| Entech Job # | 192273   |

### CONCRETE TEST

|                      |                |                          |              |                     |                   |
|----------------------|----------------|--------------------------|--------------|---------------------|-------------------|
| DD                   |                |                          | Test #: 13   |                     |                   |
| Date:                | # of Specimens | Specified Strength (psi) | Time of Test | Hours Field Cured   | Lab Receive Date: |
| 8/12/2020            | 4              | 4500                     | 1:20 PM      | 24                  | 8/13/2020         |
| <b>Specimen Type</b> |                | <b>Test Type</b>         |              | <b>Type of Cure</b> |                   |
| Cylinders 4x8        |                | Field                    |              | Lab                 |                   |
| Contractor:          |                | Supplier:                |              | Mix Design Number   |                   |
| PPC Construction     |                | Pete Lien                |              | 90DJ50              |                   |
| Truck Number         |                | Ticket Number            |              | Batch Time:         |                   |
| 2275                 |                | 974292                   |              | 12:27 PM            |                   |

Location:  
 Inlet Wall, south end inlet, Tract 7

|              |          |                    |                    |               |
|--------------|----------|--------------------|--------------------|---------------|
| Slump (in.): | Air (%): | Unit Weight (PCF): | Concrete Temp (°F) | Air Temp (°F) |
| 4.0          | 6.4      | 138.1              | 84                 | 88            |

| 7-Day Strength | 28-Day Strength | -Day Strength | 56-Day Strength | -Day Strength |
|----------------|-----------------|---------------|-----------------|---------------|
| 4460           |                 |               |                 |               |
|                |                 |               |                 |               |
|                |                 |               |                 |               |
| Average:       | Average:        | Average:      | Average:        | Average:      |
| 4460           |                 |               |                 |               |
| Break Date:    | Break Date:     | Break Date:   | Break Date:     | Break Date:   |
| 8/19/2020      | 9/9/2020        |               |                 |               |

Remarks:  
 7 Day Results

|                                  |                   |
|----------------------------------|-------------------|
| Specifications:                  | Break Sequence:   |
| 4500 PSI, 4" Max Slump, 5-8% Air | 1@7, 2@28, 1@hold |

Summary Comments:  
 PPC Construction, Pete Lien

Reviewed By: *RPJ*