



ENTECH
 ENGINEERING, INC.
 505 Elkton Drive
 Colorado Springs, CO 80907
 (719) 531-5599 • (719) 531-5238 (fax)

Client:	FLRD #5
Project:	Forest Lakes Residential Development, Filing 5
Entech Job #	192273

CONCRETE TEST

EO			Test #: 17		
Date:	# of Specimens	Specified Strength (psi)	Time of Test	Hours Field Cured	Lab Receive Date:
8/14/2020	4	4500	1:35 PM	24	8/15/2020
Specimen Type		Test Type		Type of Cure	
Cylinders 4x8		Field		Tank	
Contractor:		Supplier:		Mix Design Number	
PPC Construction		Pete Lien		90DJ50	
Truck Number		Ticket Number		Batch Time:	
997		974434		12:15 PM	

Location:
 Trickle channel, 10' northeast and 5' northwest of southwest corner of pond, southwest side of Pond C.

Slump (in.):	Air (%):	Unit Weight (PCF):	Concrete Temp (°F)	Air Temp (°F)
2.5	6.9	143.1	87	90

7-Day Strength	28-Day Strength	-Day Strength	56-Day Strength	-Day Strength
4390				
Average:	Average:	Average:	Average:	Average:
4390				
Break Date:	Break Date:	Break Date:	Break Date:	Break Date:
8/21/2020	9/11/2020			

Remarks:
 7 Day Results

Specifications:	Break Sequence:
4500 PSI, 4" Max Slump, 4.5-7.5% Air	1@7, 2@28, 1@hold

Summary Comments:
 PPC Construction, Pete Lien

Reviewed By: