



ENTECH
 ENGINEERING, INC.
 505 Elkton Drive
 Colorado Springs, CO 80907
 (719) 531-5599 • (719) 531-5238 (fax)

Client:	FLRD #5
Project:	Forest Lakes Residential Development, Filing 5
Entech Job #	192273

CONCRETE TEST

EO			Test #: 36		
Date:	# of Specimens	Specified Strength (psi)	Time of Test	Hours Field Cured	Lab Receive Date:
9/23/2020	4	4500	12:30 PM	24	9/24/2020
Specimen Type		Test Type		Type of Cure	
Cylinders 4x8		Field		Tank	
Contractor:		Supplier:		Mix Design Number	
Ideal Concrete		Action Ready Mix		A45BD67FCG	
Truck Number		Ticket Number		Batch Time:	
522		55997		11:08 AM	

Location
 Curb and gutter, south half of median on Mesa Top Drive (39.0607714, -104.9005274)

Slump (in.)	Air (%):	Unit Weight (PCF):	Concrete Temp (°F)	Air Temp (°F)
1.75	6.0	141.2	83	72
7-Day Strength	28-Day Strength	-Day Strength	56-Day Strength	-Day Strength
3910				
Average:	Average:	Average:	Average:	Average:
3910				
Break Date:	Break Date:	Break Date:	Break Date:	Break Date:
9/30/2020	10/21/2020			

Remarks:
 7 Day Results

Specifications: 4000 PSI, 5-8% Air, 4" Max Slump	Break Sequence: 1 @ 7, 2 @ 28, 1 @ hold
---	--

Summary Comments:
 Ideal Concrete, Action Ready Mix

Reviewed By: *RPJ*