



ENTECH
 ENGINEERING, INC.
 505 Elkton Drive
 Colorado Springs, CO 80907
 (719) 531-5599 • (719) 531-5238 (fax)

Client:	FLRD #5
Project:	Forest Lakes Residential Development, Filing 5
Entech Job #	192273

CONCRETE TEST

PG			Test #: 31		
Date:	# of Specimens	Specified Strength (psi)	Time of Test	Hours Field Cured	Lab Receive Date:
9/18/2020	4	4500	12:40 PM	24	9/19/2020
Specimen Type		Test Type		Type of Cure	
Cylinders 4x8		Field		Tank	
Contractor:		Supplier:		Mix Design Number	
Ideal Concrete		Action Ready Mix		A45BD67FCG	
Truck Number		Ticket Number		Batch Time:	
521		55748		11:22 AM	

Location:
 Curb and gutter, on the south side of Forest Lakes Drive, 10' west off the northwest corner of Lot 1, at (39.059911, -104.898480)

Slump (in.):	Air (%):	Unit Weight (PCF):	Concrete Temp (°F)	Air Temp (°F)
	5.0	144.2	76	72

7-Day Strength	28-Day Strength	-Day Strength	56-Day Strength	-Day Strength
4020	5490			
	5580			
Average:	Average:	Average:	Average:	Average:
4020	5540			
Break Date:	Break Date:	Break Date:	Break Date:	Break Date:
9/25/2020	10/16/2020			

Remarks:
 28 Day Results

Specifications:
 4500 PSI, 5-8% Air, 4" Max Slump
 Summary Comments:

Break Sequence:
 1@7, 2@28, 1@hold

Ideal Concrete, Action Ready Mix

Reviewed By: *RPF*

