



December 1, 2017

Ms. Nina Ruiz
El Paso County Development Services Department
2880 International Circle, Suite 110
Colorado Springs, CO 80910-3127

RE: Springs at Waterview Filing No. 1 - Follow-Up
Sketch Plan, Preliminary Plan, and Final Plat
Sec. 7, Twp. 15S, Rng. 65W, 6th P.M.
Water Division 2, Water District 10
CDWR Assigned Subdivision No. 23969

Dear Ms. Ruiz:

We have received additional information concerning the above-referenced proposal to subdivide a 15.67 +/- acre parcel into 80 single-family residential lots. The proposed supply of water for the 80 residential lots, in addition to wastewater disposal, is to be served by the Security Water and Sanitation District.

Water Supply Demand

According to the Water Supply Information Summary, Form No. GWS-76, attached as Appendix D to the May 2017 *Engineer Study for Springs at Waterview Water System Improvements*, the estimated water demand is 38.5 acre-feet/year for ordinary household purposes inside 77 single-family dwellings. **It should be noted that according to the Final Plat, it appears the development includes 85 lots.**

Source of Water Supply

The source of water for the proposed development is to be served by the Security Water and Sanitation District ("District"), and an October 31, 2017 letter from the District was provided with the submittal. According to the letter, the proposed development is within the boundaries of the District and the District has committed to serve the property a maximum of 42.5 acre-feet per year based upon 85 single family equivalents.


State Engineer's Office Opinion

According to this the latest water supply report on file with this office, it appears the District has sufficient water resources to supply this subdivision; **however, this office cannot provide favorable comments regarding the proposed water supply until the applicant provides a clear indication of the number of lots that will be created, and the estimated water demand associated with that number of lots.** Based upon the above and pursuant to Section 30-28-136(1)(h)(II), C.R.S., it is the opinion of this office that the proposed water supply cannot be provided without causing injury to decreed water rights. Should you or the applicant have any questions, please feel free to contact me directly.



Ms. Nina Ruiz
December 1, 2017
Page 2 of 2

Sincerely,

A handwritten signature in cursive script that reads "Caleb Foy".

Caleb Foy, P.E.
Water Resource Engineer

cc: Steve Witte, Division 2 Engineer (via email)
Doug Hollister, District 10 Water Commissioner (via email)

CRF:crf