

Colorado Springs
5170 Mark Dabling Blvd
Colorado Springs, CO 80918
Phone: 719-528-8300

Client:
Sub4 Development Corporation
2301 West Bradley Avenue Suite 2
Champaign, IL 61821

Project:
CS19163.001F-360
Solace Colorado Springs
Powers Boulevard and Galley Road
Colorado Springs, CO

Activity Date: 07/18/2022

Technician: Murton, Bryceann

Placement Location: 1225 Paonia Street, west of entrance

Plans/Details: RF-15 and RF15A

Items Observed:

Placement Type Observed:

- Grade Beam
- Pier Cap
- Column
- Structural Slab
- Slab on Grade
- Slab on Deck
- Footing
- Wall
- Other

Items Checked:

- Bar Size
- Bar Quantity and Spacing
- Lap Length
- Cover
- Form Void
- Dowel Bars
- Other

Conformance:

The items observed were found to be in general conformance with the approved drawings and standard construction practice:

Yes No

Discrepancy:

Yes No

General Remarks:

During the requested site visit, CTL Thompson observed foundation wall on the east side of entrance. Kevin with Sub4 Development Corporation was notified if the test results.

Colorado Springs
5170 Mark Dabling Blvd
Colorado Springs, CO 80918
Phone: 719-528-8300

Client:
Sub4 Development Corporation
2301 West Bradley Avenue Suite 2
Champaign, IL 61821

Project:
CS19163.001F-360
Solace Colorado Springs
Powers Boulevard and Galley Road
Colorado Springs, CO

Images:

