

**Report #:** SNG-000072  
**Test date:** 07/20/22  
**Report Date:** 07/22/2022  
**Test Method:** ASTM D 6938

**Client:**  
 Sub4 Development Corporation  
 2301 West Bradley Avenue Suite 2  
 Champaign, IL 61821

**Project:**  
 CS19163.001F-345  
 Solace Colorado Springs  
 Powers Boulevard and Galley Road  
 Colorado Springs, CO

Colorado Springs  
 5170 Mark Dabbling Blvd  
 Colorado Springs, CO 80918  
 Phone: 719-528-8300

**Test Results**

Test #	Retest Of	Test Date	Proctor ID	Method	Soil Classification	Optimum Moisture (%)	Maximum Dry Density (pcf)	In Place Moisture (%)	In Place Dry Density (pcf)	In Place Wet Density (pcf)	Probe Depth (in)	Percent Compaction	Min Comp. (%)	Optimum Moisture Tolerance (%)	Remark
176		07/20/22	1	1557B	Granular	7.7	130.0	7.6	123.2	132.6	8	95	95	-2 / 2	A
177		07/20/22	1	1557B	Granular	7.7	130.0	7.5	122.9	132.1	8	95	95	-2 / 2	A

**Test Information**

Test #	Test Location	Elevation	Reference	Gauge Make / Model / SN / Calibrated	Field Technician
176	Retaining Wall Backfill: Channel Cutoff Wall (outside)	0.0	Below Proposed Grade	XPLORER / 3500 / 1993 / 08/31/2021	Wheatley, Zachary
177	Retaining Wall Backfill: Channel Cutoff Wall (inside)	0.0	Below Proposed Grade	XPLORER / 3500 / 1993 / 08/31/2021	Wheatley, Zachary

Remarks	Comments
A: Test results comply with specifications.	Tests are "Direct Transmission" (Method A) unless probe depth is noted as "Backscatter". Gauge calibration data on file with the testing agency. <b>177:</b> During the requested site visit, CTL Thompson observed the contractor moisture conditioning and applying compaction effort to the channel cutoff wall. Weather: sunny and 96 degrees F.