

Report #: SNG-000060
Test date: 06/30/22
Report Date: 07/05/2022
Test Method: ASTM D 6938

Client:
 Sub4 Development Corporation
 2301 West Bradley Avenue Suite 2
 Champaign, IL 61821

Project:
 CS19163.001F-345
 Solace Colorado Springs
 Powers Boulevard and Galley Road
 Colorado Springs, CO

Colorado Springs
 5170 Mark Dabling Blvd
 Colorado Springs, CO 80918
 Phone: 719-528-8300

Test Results

Test #	Retest Of	Test Date	Proctor ID	Method	Soil Classification	Optimum Moisture (%)	Maximum Dry Density (pcf)	In Place Moisture (%)	In Place Dry Density (pcf)	In Place Wet Density (pcf)	Probe Depth (in)	Percent Compaction	Min Comp. (%)	Optimum Moisture Tolerance (%)	Remark
161		06/30/22	1	1557B	Granular	7.7	130.0	8.4	123.3	133.7	8	95	95	-2 / 2	A
162		06/30/22	1	1557B	Granular	7.7	130.0	7.4	123.8	133.0	8	95	95	-2 / 2	A

Test Information

Test #	Test Location	Elevation	Reference	Gauge Make / Model / SN / Calibrated	Field Technician
161	Waterline Trench Backfill: Tie-in, north end of Paonia extension.	2.0	Below Proposed Grade	XPLORER / 3500 / 1993 / 08/31/2021	Wheatley, Zachary
162	Waterline Trench Backfill: Tie-in, north end of Paonia extension.	0.0	Below Proposed Grade	XPLORER / 3500 / 1993 / 08/31/2021	Wheatley, Zachary

Remarks	Comments
A: Test results comply with specifications.	Tests are "Direct Transmission" (Method A) unless probe depth is noted as "Backscatter". Gauge calibration data on file with the testing agency. 162: During the requested site visit, CTL Thompson observed the contractor moisture conditioning and applying compaction effort to the water tie-in backfill. Weather: sunny and 84 degrees F.