



Prevent • Promote • Protect

Environmental Health Division
1675 W. Garden of the Gods Road
Suite 2044
Colorado Springs, CO 80907
(719) 578-3199 *phone*
(719) 578-3188 *fax*
www.elpasocountyhealth.org

7525 Falcon Meadows Blvd., PPR-24-16

Please accept the following comments from El Paso County Public Health (EPCPH) regarding the project referenced above:

- A record of an approved, permitted on-site wastewater treatment system (OWTS) for this property indicates the original OWTS was installed and approved in 1997 for a 5-bedroom house.
- Restroom facilities and water service are not planned for the new meditation hall. The Letter of Intent indicated the restroom inside the existing building will be used. As noted above the existing building was not approved for commercial use, such as a temple or meditation hall; therefore, the existing system must be evaluated for adequacy by a Colorado Registered Engineer with a letter provided to El Paso County Public Health (EPCPH) approving it for use by the maximum population as determined by the engineer. Please contact EPCPH with any questions on OWTS requirements.
- Please ensure all components of the existing OWTS are located and protected from vehicular traffic, parking, and construction traffic associated with the new meditation hall.

Mike McCarthy
El Paso County Public Health
719-332-5771
mikemccarthy@elpasoco.com
19July2024