



ORIGINAL PERMIT APPLICANT(S)

BEVERLY C HARRISON

APPROVED WELL LOCATION

Water Division: 2 Water District: 10
 Designated Basin: N/A
 Management District: N/A
 County: EL PASO
 Parcel Name: COLORADO SPRINGS FLY CASTING CLUB
 Lot: 7 Block: Filing:
 Physical Address: 8855 CARROLL LAKES RD WOODLAND PARK, CO 80863
 NE 1/4 SW 1/4 Section 10 Township 12.0 S Range 68.0 W Sixth P.M.

Well to be constructed on specified tract of land

PERMIT TO CONSTRUCT A NEW WELL

ISSUANCE OF THIS PERMIT DOES NOT CONFER A WATER RIGHT
CONDITIONS OF APPROVAL

- 1) This well shall be used in such a way as to cause no material injury to existing water rights. The issuance of this permit does not assure the applicant that no injury will occur to another vested water right or preclude another owner of a vested water right from seeking relief in a civil court action.
- 2) The construction of this well shall be in compliance with the Water Well Construction Rules 2 CCR 402-2, unless approval of a variance has been granted by the State Board of Examiners of Water Well Construction and Pump Installation Contractors in accordance with Rule 18.
- 3) Approved pursuant to CRS 37-92-602(3)(b)(II)(A) as the only well on a residential site represented as a 1/50th share of a 177.50 acre parcel known as Lot 7 of the Colorado Springs Fly Casting Club, El Paso County.
- 4) The use of ground water from this well is limited to ordinary household purposes inside one single family dwelling. The ground water shall not be used for irrigation or other purposes.
- 5) The maximum pumping rate of this well shall not exceed 15 GPM.
- 6) The return flow from the use of this well must be through an individual waste water disposal system of the non-evaporative type where the water is returned to the same stream system in which the well is located.
- 7) Pursuant to Rule 6.2.3 of the Water Well Construction Rules, the well construction contractor shall submit the as-built well location on work reports required by Rule 17.1 within 60 days of completion of the well. The measured location must be accurate to 200 feet of the actual location. The location information must include a GPS location (UTM coordinates) pursuant to the Division of Water Resources' guidelines.

NOTE: This permit will expire on the expiration date unless the well is constructed by that date. A Well Construction and Yield Estimate Report (GWS-31) must be submitted to the Division of Water Resources to verify the well has been constructed. An extension of the expiration date may be available. Contact the DWR for additional information or refer to the extension request form (GWS-64) available at: <http://www.water.state.co.us>

NOTICE: This permit has been approved subject to the following changes: The quarter/quarter and quarter section were determined from county records. You are hereby notified that you have the right to appeal the issuance of this permit, by filing a written request with this office within sixty (60) days of the date of issuance, pursuant to the State Administrative Procedures Act. (See Section 24-4-104 through 106, C.R.S.)

NOTE: Expired permit no. 296086 was previously issued for this lot.

Issued By **GEOFFREY DAVIS**

Date Issued: 7/15/2019
 Expiration Date: 7/15/2021