



COLORADO
Division of Water Resources
Department of Natural Resources

WELL PERMIT NUMBER 185024-
RECEIPT NUMBER 0379274

ORIGINAL PERMIT APPLICANT(S)

RICK PRING

APPROVED WELL LOCATION

Water Division: 2 Water District: 10
Designated Basin: UPPER BLACK SQUIRREL CREEK
Management District: UPPER BLACK SQUIRREL
County: EL PASO
Parcel Name: N/A
Physical Address: N/A

NE 1/4 NE 1/4 Section 24 Township 12.0 S Range 65.0 W Sixth P.M.

UTM COORDINATES (Meters, Zone:13, NAD83)

Easting: 533690.6 Northing: 4316319.5

ISSUANCE OF THIS PERMIT DOES NOT CONFER A WATER RIGHT

CONDITIONS OF APPROVAL

- 1) This well shall be used in such a way as to cause no material injury to existing water rights. The issuance of this permit does not ensure that no injury will occur to another vested water right or preclude another owner of a vested water right from seeking relief in a civil court action.
- 2) The construction of this well shall be in compliance with the Water Well Construction Rules 2 CCR 402-2, unless approval of a variance has been granted by the State Board of Examiners of Water Well Construction and Pump Installation Contractors in accordance with Rule 17.
- 3) Approved pursuant to CRS 37-90-105.
- 4) **CONDITION REVOKED ON 03/17/2021 REPLACED BY CONDITION #5.**
Water from this well may be used for domestic purposes inside one (1) single family dwelling.
- 5) Water from this well may be used for domestic purposes inside 2 single family dwellings.
- 6) The maximum pumping rate of this well shall not exceed 15 GPM.
- 7) The annual appropriation shall not exceed 1 acre-foot.
- 8) The irrigated area shall not exceed 1 acre (43,560 square feet) of lawn and garden.
- 9) Water from this well may be used for the watering of livestock on range and pasture.
- 10) Production from is limited to the Dawson aquifer. Plain casing must be installed and sealed from ground surface to minimum depth of 110 feet to prevent diversion of water production from other zones. The depth of the well shall not exceed 595 feet, which is the estimated base of the Dawson aquifer.
- 11) This well must be constructed within 300 feet of the location specified on this permit.

[See Original Permit](#)

Date Issued: 2/16/1995

Issued By _____

Expiration Date: 2/16/1997

PERMIT HISTORY

03-17-2021 PERMIT AMENDMENT (CONDITIONS)