



El Paso County MS4 Post Construction Detention / Water Quality Facility Documentation Form

This document **must be completed and submitted** with required attachments to the County for projects requiring a detention and/or a water quality facility. A separate completed form must be submitted for each facility.

Project name: Hillside at Lorson Ranch – Pond E1 (updated from previously submitted pond)

Owner name: Lorson Ranch Metropolitan District

Location Address: 212 N. Wahsatch Avenue, Suite 301

Latitude and Longitude:

Latitude: 38°43'56.38"N, Longitude: 104°37'31.32"W

Assessor's Parcel #: 5500000282 Section: 24 Township: 15 South Range: 65 West

Expected Completion date: December, 2022

Project acreage: 128.328 acres Design Ponding Acres: 1.92acres Design Storm: 100-year

Design Engineer Email Address: rich@ceg1.com

To ensure compliance with C.R.S. 37-92-602(8), the completed Stormwater Detention and Infiltration Design Data Sheet **must be attached**. The form can be found here: <https://maperture.digitaldataservices.com/gvh/?viewer=cswdif#> (click on Download SDI Design Data Sheet)

List all permanent water quality control measure(s) (EDBs, rain gardens, etc):
Pond E1 is an Extended Detention Basin with only existing undeveloped overland flows entering the pond. An outlet structure for Water quality capture volume will be added when upstream development occurs . The detention pond has been sized in accordance with future full spectrum designs requirements for fully developed tributary areas. Interim flows have been modeled for this pond. The interim outlet structure is a 24" RCP storm sewer.

For all projects for which the constrained redevelopment sites standard is applied, provide an explanation of why it is not practicable to meet the full design standards. Answer: full design standards will be achieved when tributary area is developed and a full spectrum outlet structure is constructed.

Attach Operations and Maintenance (O&M) Plan describing the operation and maintenance procedures that ensure the long-term observation, maintenance, and operation of control measure(s), including routine inspection frequencies and maintenance activities. If multiple, different water quality control measures are used at the same location, a separate O & M Plan must be provided for each facility.

Attach Private Detention Basin / Stormwater Quality Best Management Practice Maintenance Agreement and Easement addressing maintenance of BMPs that shall be binding on all subsequent owners of the permanent BMPs.

Attachments:

- Stormwater Detention and Infiltration Design Data Sheet
- O & M Plan
- Maintenance and Access Agreement

Review Engineer

EPC Project File No.



El Paso County MS4 Post Construction Detention / Water Quality Facility Documentation Form

This document **must be completed and submitted** with required attachments to the County for projects requiring a detention and/or a water quality facility. A separate completed form must be submitted for each facility.

Project name: Hillside at Lorson Ranch– Pond G

Owner name: Lorson Ranch Metropolitan District

Location Address: 212 N. Wahsatch Avenue, Suite 301

Latitude and Longitude:

Latitude: 38°43'49.4"N, Longitude: 104°36'48.7"W

Assessor's Parcel #: 5500000370 Section: 24 Township: 15 South Range: 65 West

Expected Completion date: December, 2022

Project acreage: 128.328 acres Design Ponding Acres: 0.18acres Design Storm: 100-year

Design Engineer Email Address: rich@ceg1.com

To ensure compliance with C.R.S. 37-92-602(8), the completed Stormwater Detention and Infiltration Design Data Sheet **must be attached**. The form can be found here: <https://maperture.digitaldataservices.com/gvh/?viewer=cswdif#> (click on Download SDI Design Data Sheet)

List all permanent water quality control measure(s) (EDBs, rain gardens, etc):

Pond G is an Extended Detention Basin with developed flows entering the pond. The pond includes an outlet structure for Water quality capture volume and for detention. The detention pond has been sized in accordance with full spectrum design for fully developed tributary areas. The release rates have been adjusted to match existing flows draining south offsite into the Upper Williams Creek drainage basin.

For all projects for which the constrained redevelopment sites standard is applied, provide an explanation of why it is not practicable to meet the full design standards. Answer: full design standards are achieved and a full spectrum outlet structure is constructed.

Attach Operations and Maintenance (O&M) Plan describing the operation and maintenance procedures that ensure the long-term observation, maintenance, and operation of control measure(s), including routine inspection frequencies and maintenance activities. If multiple, different water quality control measures are used at the same location, a separate O & M Plan must be provided for each facility.

Attach Private Detention Basin / Stormwater Quality Best Management Practice Maintenance Agreement and Easement addressing maintenance of BMPs that shall be binding on all subsequent owners of the permanent BMPs.

Attachments:

Stormwater Detention and Infiltration Design Data Sheet
O & M Plan
Maintenance and Access Agreement

Review Engineer : GR
EPC Project File No. . PUD/SP 22-001



El Paso County MS4 Post Construction Detention / Water Quality Facility Documentation Form

This document **must be completed and submitted** with required attachments to the County for projects requiring a detention and/or a water quality facility. A separate completed form must be submitted for each facility.

Project name: Hillside at Lorson Ranch– Pond H

Owner name: Lorson Ranch Metropolitan District

Location Address: 212 N. Wahsatch Avenue, Suite 301

Latitude and Longitude:

Latitude: 38°43'49.4"N, Longitude: 104°37'04.5"W

Assessor's Parcel #: 5500000370 Section: 24 Township: 15 South Range: 65 West

Expected Completion date: December, 2022

Project acreage: 128.328 acres Design Ponding Acres: 0.35acres Design Storm: 100-year

Design Engineer Email Address: rich@ceg1.com

To ensure compliance with C.R.S. 37-92-602(8), the completed Stormwater Detention and Infiltration Design Data Sheet **must be attached**. The form can be found here: <https://maperture.digitaldataservices.com/gvh/?viewer=cswdif#> (click on Download SDI Design Data Sheet)

List all permanent water quality control measure(s) (EDBs, rain gardens, etc):

Pond H is an Extended Detention Basin with developed flows entering the pond. The pond includes an outlet structure for Water quality capture volume and for detention. The detention pond has been sized in accordance with full spectrum design for fully developed tributary areas. The release rates have been adjusted to match existing flows draining south offsite into the Upper Williams Creek drainage basin.

For all projects for which the constrained redevelopment sites standard is applied, provide an explanation of why it is not practicable to meet the full design standards. Answer: full design standards are achieved and a full spectrum outlet structure is constructed.

Attach Operations and Maintenance (O&M) Plan describing the operation and maintenance procedures that ensure the long-term observation, maintenance, and operation of control measure(s), including routine inspection frequencies and maintenance activities. If multiple, different water quality control measures are used at the same location, a separate O & M Plan must be provided for each facility.

Attach Private Detention Basin / Stormwater Quality Best Management Practice Maintenance Agreement and Easement addressing maintenance of BMPs that shall be binding on all subsequent owners of the permanent BMPs.

Attachments:

Stormwater Detention and Infiltration Design Data Sheet
O & M Plan
Maintenance and Access Agreement

Review Engineer : GR
EPC Project File No. . PUD/SP 22-001