Symbol	Label	Image	Quantity	Manufacturer	Catalog Number	Description	Number Lamps	Lumens Per Lamp	Light Loss Factor	Wattage	Plot
	A		3	Lithonia Lighting	WDGE4 LED P1 70CRI R3 40K	WDGE4 LED WITH P1 - PERFORMANCE PACKAGE, 4000K, 70CRI, TYPE 3 OPTIC	1	11883	0.9	76.21	Max: 8243cd
	В		Ji J	Lithonia Lighting	WDGE1 LED P1 40K 80CRI VF	WDGE1 LED WITH P1 - PERFORMANCE PACKAGE, 4000K, 80CRI, VISUAL COMFORT FORWARD OPTIC	1	1227	0.9	10.0002	Max: 854cd
		W)i	Lithonia Lighting	WDGE2 LED P3 40K 70CRI T1S	WDGE2 LED WITH P3 - PERFORMANCE PACKAGE, 4000K, 70CRI, TYPE 1 SHORT	1	3486	0.9	32.1375	Max: 3696cd

Statistics											
Description	Symbol	Avg	Min	Max/Min	Avg/Min	Max					
Attendant Shelter	+	0.1 fc	0.0 fc	N/A	N/A	5.0 fc					
Property Line +20 Feet	+	0.0 fc	0.0 fc	N/A	N/A	0.1 fc					



GENERAL NOTES

- A. DRAWINGS ARE BASED ON RECORD DRAWINGS (NOT GUARANTEED TO BE CURRENT AT TIME OF CONSTRUCTION) AND FIELD INVESTIGATION WITH DEMOLITION. EXAMINE PLANS AND VISIT THE SITE TO FIELD VERIFY ACTUAL CONDITIONS AND COORDINATE SAME WITH OTHER TRADES PRIOR TO STARTING
- B. A LICENSED AND BONDED CONTRACTOR SHALL BE USED FOR INSTALLATION. ALL LOCAL CODES SHALL BE FOLLOWED DURING INSTALLATION.
- C. ALL LIGHTING FIXTURES SHALL BE FULL CUT-OFF OR HAVE SHIELDING TO REDUCE OFF-SITE LIGHTING IMPACTS ONTO ADJACENT PROPERTIES AND ROADWAYS. ALL EXTERIOR LIGHTING SHALL BE ARRANGED TO MITIGATE LIGHT DIRECTED AWAY FROM ADJACENT PROPERTIES AND ANY PUBLIC RIGHT-OF-WAY. AN AMENDMENT TO THIS PLAN MAY BE REQUIRED IF THE LIGHTING TYPE IS CHANGED.

KEYNOTES

- LIGHTING FOR THE WALKWAYS WILL BE PROVIDED BY WALL-MOUNTED DOWN CASTING FIXTURES LOCATED ON PROPOSED BUILDING. FINAL LOCATION TO BE DETERMINED DURING BUILDING DESIGN.
- EXTERIOR LIGHTING, EXCEPT SECURITY LIGHTING, WILL BE CONTROLLED BY A TIME CLOCK TO BE TURNED OFF DURING NON-OPERATING HOURS.


hiartano Engineering Group

ENGINEER SEAL:

10186 MT. LINCOLN DR. PEYTON, CO 80831 INFO@CHIARTANOEG.COM 719.257.2091

FER STATION

BARBARICK WASTE TRANSF 8812 CLIFF ALLEN PT. COLORADO SPRINGS. CO



PROJECT NO:
DRAWN BY:
CHECKED BY:
DATE:

SHEET CONTENTS:

SHEET CONTENT

SITE PHOTOMETRIC PLAN

10/23/2023

SHEET NUMBER:

E100