



**COLORADO**  
Division of Water Resources  
Department of Natural Resources

May 5, 2021

El Paso County Development Services Department  
2880 International Circle, Suite 110  
Colorado Springs, CO 80910

RE: Meadowbrook Park  
SE1/4 of Sec. 8, Twp. 14S, Rng. 65W, 6<sup>th</sup> P.M.  
Water Division 2, Water District 10  
CDWR Assigned Referral No. 27430

To Whom It May Concern:

We have received the submittal concerning the above referenced proposal create a subdivision in El Paso County. According to the materials, it appears the development consists of 70 industrial lots with irrigated open areas on 8.1 +/- acres. This office has no record of any existing wells located on the property. The proposed source of water supply and wastewater disposal is to be served by the Cherokee Metropolitan District (“Cherokee”).

This office previously provided written comments, dated December 14, 2020, regarding the proposed development during the preliminary planning stage. The current referral does not change the water supply requirements for the subdivision; therefore, please refer to our previous comments attached to this letter.

Should you or the applicant have questions regarding any of the above, please feel free to contact me at this office.

Sincerely,

Kate Fuller, P.E.  
Water Resource Engineer

ec: Bill Tyner, Division 2 Engineer  
Doug Hollister, District 10 Water Commissioner





December 14, 2020

El Paso County Planning Department  
 2880 International Circle  
 Colorado Spring, CO 80910

RE: Meadowbrook Park  
 SE1/4 of Sec. 8, Twp. 14S, Rng. 65W, 6<sup>th</sup> P.M.  
 Water Division 2, Water District 10  
 CDWR Assigned Referral No. 27430

To Whom It May Concern:

We have received a referral regarding the above referenced proposal to subdivide an existing 8.1 acre tract of land into 70 industrial lots with irrigated open areas. According to the submittal, the proposed supply of water and wastewater disposal is to be served by Cherokee Metropolitan District (“Cherokee”).

**Water Supply Demand**

The Water Supply Information Summary, Form No. GWS-76 was included with the submittal. There are some inconsistencies in the submittal about the area of land that will be irrigated. However, the Subdivision Summary Form and the Water Resource Report estimated the water supply needs as follows:

Use	Amount	Water Use Rate	Demand (acre-foot/year)
Residences	70 units	0.22 AF per unit	15.4
Irrigation, fully watered	0.88 acres	0.06 AF/year per 1,000 square-feet	2.23
Irrigation, reduced watering	1.07 acres	0.02 AF/year per 1,000 square-feet	1.08
<b>Total</b>			<b>18.7</b>

Please note that standard water use rates, as found in the Guide to Colorado Well Permits, Water Rights, and Water Administration, are 0.3 acre-foot/year for each ordinary household, 0.05 acre-foot/year for four large domestic animals, and 0.05 acre-foot/year for each 1,000 square feet of lawn and garden irrigation.

**Source of Water Supply**

The source of water for the proposed development will be Cherokee Metropolitan District. A letter of commitment from Cherokee, dated September 21, 2020, was provided with the referral materials indicating that Cherokee is committed to providing 18.7 acre-foot/year to the proposed subdivision.



According to the records of this office, Cherokee has sufficient water resources to supply this development as described above.

### **Additional Comments**

Should the development include construction and/or modification of any storm water structure(s), the applicant should be aware that, unless the structure can meet the requirements of a “storm water detention and infiltration facility” as defined in section 37-92-602(8), Colorado Revised Statutes, the structure may be subject to administration by this office. The applicant should review DWR’s *Administrative Statement Regarding the Management of Storm Water Detention Facilities and Post-Wildland Fire Facilities in Colorado*, located at <https://dnrweblink.state.co.us/dwr/ElectronicFile.aspx?docid=3576581&dbid=0> to ensure that the notification, construction and operation of the proposed structure meets statutory and administrative requirements. The applicant is encouraged to use *Colorado Stormwater Detention and Infiltration Facility Notification Portal*, located at <https://maperture.digitaldataservices.com/gvh/?viewer=cswdif>, to meet the notification requirements.

### **State Engineer’s Office Opinion**

Pursuant to Section 30-28-136(1)(h)(II) C.R.S., it is the opinion of this office that the proposed water supply can be provided without causing injury to decreed water rights, and the supply is expected to be adequate. Should you or the applicant have questions regarding any of the above, please feel free to contact me directly.

Sincerely,



Kate Fuller, P.E.  
Water Resource Engineer

Cc: Bill Tyner, Division Engineer  
Doug Hollister, Water Commissioner District 10