



Prevent • Promote • Protect

Environmental Health Division  
1675 W. Garden of the Gods Road  
Suite 2044  
Colorado Springs, CO 80907  
(719) 578-3199 *phone*  
(719) 578-3188 *fax*  
[www.elpasocountyhealth.org](http://www.elpasocountyhealth.org)

**Helton Mini Storage Minor Subdivision, MS-17-004;**  
**Comments Updated 04Dec2017**

Please accept the following comments from El Paso County Public Health for the 7.6 acre, minor subdivision project referenced above:

- Water service is not proposed for this temporary storage facility. Water for the office worker is proposed to be provided by bottled water.
- Wastewater service is proposed to be provided by a portable toilet for the office worker during business hours. El Paso County Public Health (EPCPH) will require an approved method of wastewater treatment and/or storage for longer term use to be submitted to EPCPH within 1 year of the issuance of the Certificate of Occupancy by the Pikes Peak Regional Building Department.
- El Paso County Public Health can approve a portable toilet for what could be considered temporary use.

Mike McCarthy, R.E.H.S.  
El Paso County Public Health Environmental Health Division  
719.575.8602  
[mikemccarthy@elpasoco.com](mailto:mikemccarthy@elpasoco.com)  
19Nov2017  
Updated: 04Dec2017