



Prevent • Promote • Protect

Environmental Health Division  
1675 W. Garden of the Gods Road  
Suite 2044  
Colorado Springs, CO 80907  
(719) 578-3199 *phone*  
(719) 578-3188 *fax*  
[www.elpasocountyhealth.org](http://www.elpasocountyhealth.org)

### **Super Star Car Wash SDP, PPR-23-15**

Please accept the following comments from El Paso County Public Health for the special use request referenced above:

- Water service will be provided by the Cherokee Metropolitan District (CMD). There is a finding for sufficiency in terms of water quality for this Colorado Department of Public Health and Environment (CDPHE), Water Quality Control Division, approved community water system. The CDPHE has assigned PWSID #CO-0121125 to the CMD.
- Wastewater service for the project is provided by Cherokee Metropolitan District. The district has sufficient capacity to treat the wastewater flow projected for the project.
- Earthmoving activity more than one acre, but less than twenty-five acres, requires a local Construction Activity Permit from El Paso County Public Health. Go to <https://www.elpasocountyhealth.org/service/air-quality/construction-activity-application> for more information.
- The water quality basin must have mosquito control responsibilities included as a part of the construction design and maintenance plan to help control mosquito breeding habitat and minimize the potential for West Nile Virus.

Mike McCarthy  
El Paso County Public Health  
719-332-5881  
[mikemccarthy@elpasoco.com](mailto:mikemccarthy@elpasoco.com)  
27May2023