



Prevent • Promote • Protect

Environmental Health Division
1675 W. Garden of the Gods Road
Suite 2044
Colorado Springs, CO 80907
(719) 578-3199 *phone*
(719) 578-3188 *fax*
www.elpasocountyhealth.org

Meadow Lake Industrial Park, I-20-1

Please accept the following updated comments from El Paso County Public Health (EPCPH) regarding the 160.7-acre project referenced above:

- Water and wastewater services for the development have not yet been identified. There are several surrounding water and wastewater districts being evaluated for supply/capacity, existing IGA's, infrastructure costs and timing of the development.
- Earthmoving activities greater than 25 acres require a Construction Activity Permit from the Colorado Department of Public Health and Environment, Air Pollution Control Division. Go to:
<https://www.colorado.gov/pacific/cdphe/general-air-permits>
- Radon resistant construction building techniques/practices are encouraged to be used in this area. The EPA has determined that Colorado, and specifically the El Paso County area, have higher radon levels than other areas of the country.
- Water quality basins, if any, must have mosquito control included as a part of the construction design and maintenance plan to help control mosquito breeding areas and minimize the potential for West Nile Virus.

Mike McCarthy
El Paso County Public Health
mikemccarthy@elpasoco.com
719-575-8602
22May2020