

OFFICE OF THE STATE ENGINEER
COLORADO DIVISION OF WATER RESOURCES

818 Centennial Bldg., 1313 Sherman St., Denver, Colorado 80203
(303) 866-3581

781

WELL PERMIT NUMBER	164691
DIV. <u>8</u> CNTY. <u>21</u> WD <u>10</u> DES. BASIN <u>4</u> MD <u>12</u>	

APPLICANT

JERRY & NANCY MANLEY
4645 N CURTIS RD
PEYTON, CO 80831

719/683-2173

Lot: Block: Filing: Subdiv:

APPROVED WELL LOCATION

COUNTY EL PASO

SW 1/4 SW 1/4 Section 22
Twp 13 S, Range 64 W 6thP.M.

DISTANCES FROM SECTION LINES

700 Ft. from South Section Line
350 Ft. from West Section Line

CHANGE/EXPANSION OF USE

CONDITIONS OF APPROVAL

- 1) This well shall be used in such a way as to cause no material injury to existing water rights. The issuance of the permit does not assure the applicant that no injury will occur to another vested water right or preclude another owner of a vested water right from seeking relief in a civil court action.
- 2) The construction of this well shall be in compliance with the Water Well Construction and Pump Installation Rules 2 CCR 402-2, unless approval of a variance has been granted by the State Board of Examiners of Water Well Construction and Pump Installation Contractors in accordance with Rule 17.
- 3) Approved pursuant to CRS 37-90-105 to expand the use of a well constructed with Permit No. 34943.
- 4) Water from this well may be used for domestic purposes inside three (3) single family dwellings.
- 5) The maximum pumping rate shall not exceed 15 GPM.
- 6) The annual appropriation shall not exceed 1 acre-feet.
- 7) The irrigated area shall not exceed 1 acre of lawn and garden.
- 8) Water from this well may be used for the watering of livestock on range and pasture.
- 9) Production is limited to the Denver aquifer.
- 10) This well must be constructed within 300 feet of the location specified on this permit.
- 11) A totalizing flow meter must be installed on the well and maintained in good working order. Permanent records of all diversions must be maintained by the well owner (collected at least annually) and submitted to the Upper Black Squirrel Ground Water Management District and the Division of Water Resources upon request.
- 12) Issuance of this permit cancels permit no. 34943. RAC 6-10-92

APPROVED:
RAC

Hal D. Simpson

State Engineer (Acting)

Receipt No. 0337789

DATE ISSUED JUN 11 1992

[Signature]

By

EXPIRATION DATE JUN 11 1994