



June 29, 2023

Kylie Bagley
El Paso County Development Services
2880 International Circle, Suite 110
Colorado Springs, CO 80910

SUBJECT: Engineering Review Comment
Mountain View Electric Association Inc. (MVEA)

To El Paso County:

MVEA has these comments about the following:

Project Name: Manley Subdivision Filing 2 – Minor Subdivision

Project Number: VR2310

Description: A partial replat of Lot 2 of Filing 1 located on the northwest corner of Curtis Rd. and Jones Rd. in Township 13S, Range 64W, Section 22.

This area is within the MVEA's certificated service area. MVEA will serve this area according to our Line Extension policy. Connection requirements may include provisions for necessary line extensions and or other system improvements, and payment of all fees under the Line Extension Policy. Information concerning these requirements can be obtained by contacting the Engineering Department.

MVEA requests a ten (10) foot front, side, and rear lot utility easements and all tracts, along with a twenty (20) foot exterior utility easement on the plat. In addition, a ten (10) foot easement adjacent to all access easements. MVEA also requests the platting of MVEA's existing facilities with easements on the plat. Additional easements may be required.

MVEA has existing facilities near and within this parcel of land. If there is any damage, removal or relocation of facilities it will be at the expense of the applicant.

If additional information is required, please contact me at (719) 494-2636. Our office hours are 7:00 a.m. to 5:30 p.m., Monday – Thursday.

Sincerely,

Gina Perry
Engineering Coordinator

This Association is an equal opportunity provider and employer.