



# SF17023-V2b-CDs.pdf Markup Summary

dsdrice (8)




**Subject:** Cloud+  
**Page Label:** 19  
**Lock:** Unlocked  
**Status:**  
**Checkmark:** Unchecked  
**Author:** dsdrice  
**Date:** 2/27/2018 12:41:25 PM  
**Color:** ■

If deviation request is not approved, sidewalk is required.




**Subject:** Callout  
**Page Label:** 24  
**Lock:** Unlocked  
**Status:**  
**Checkmark:** Unchecked  
**Author:** dsdrice  
**Date:** 2/27/2018 9:50:13 PM  
**Color:** ■

ROW line is missing/moved.



**Subject:** Image  
**Page Label:** 24  
**Lock:** Unlocked  
**Status:**  
**Checkmark:** Unchecked  
**Author:** dsdrice  
**Date:** 2/27/2018 2:35:13 PM  
**Color:** ■

(This is from the PUD)




**Subject:** Callout  
**Page Label:** 24  
**Lock:** Unlocked  
**Status:**  
**Checkmark:** Unchecked  
**Author:** dsdrice  
**Date:** 2/27/2018 9:53:51 PM  
**Color:** ■

Provide complete details including connections, elevation plans, rebar, etc., or add note that shop drawings will be required prior to construction.




**Subject:** Cloud+  
**Page Label:** 25  
**Lock:** Unlocked  
**Status:**  
**Checkmark:** Unchecked  
**Author:** dsdrice  
**Date:** 2/27/2018 9:47:49 PM  
**Color:** ■

If easement is not vacated, show through ROW.



**Subject:** Cloud+  
**Page Label:** 30  
**Lock:** Unlocked  
**Status:**  
**Checkmark:** Unchecked  
**Author:** dsdrice  
**Date:** 2/27/2018 12:37:08 PM  
**Color:** ■


in



---

**Subject:** Cloud+  
**Page Label:** 32  
**Lock:** Unlocked  
**Status:**  
**Checkmark:** Unchecked  
**Author:** dsdrice  
**Date:** 2/27/2018 12:39:38 PM  
**Color:** ■

in



---

**Subject:** Arrow  
**Page Label:** 33  
**Lock:** Unlocked  
**Status:**  
**Checkmark:** Unchecked  
**Author:** dsdrice  
**Date:** 2/27/2018 12:41:46 PM  
**Color:** ■

North