



Prevent • Promote • Protect

Environmental Health Division
1675 W. Garden of the Gods Road
Suite 2044
Colorado Springs, CO 80907
(719) 578-3199 *phone*
(719) 578-3188 *fax*
www.elpasocountyhealth.org

Forest Lakes Water Treatment Facility, PPR-17-043

Please accept the following comments from El Paso County Public Health for the project referenced above:

- The construction of the water treatment facility must meet all the design criteria of the Colorado Department of Public Health and Environment, Water Quality Control Division.
- Per Wright Water Engineers, Inc., the water treatment facility will have wastewater service provided by the Upper Monument Creek Regional Wastewater Treatment Facility. There is an employee restroom planned for the water treatment plant.
- Earthmoving activity in excess of one acre, but less than twenty-five acres, will require a Construction Activity Permit from El Paso County Public Health. Go to <http://www.elpasocountyhealth.org/service/air-quality> for more information.

Mike McCarthy, R.E.H.S.
El Paso County Public Health
Environmental Health Division
719.575.8602
mikemccarthy@elpasoco.com
17Oct2017