



Prevent • Promote • Protect

Environmental Health Division  
1675 W. Garden of the Gods Road  
Suite 2044  
Colorado Springs, CO 80907  
(719) 578-3199 *phone*  
(719) 578-3188 *fax*  
[www.elpasocountyhealth.org](http://www.elpasocountyhealth.org)

**Woodmen Hills Metropolitan District West Water Tank at Arroya Lane, PPR-20-7**

Please accept the following comments from El Paso County Public Health for the project referenced above:

- The construction of the water storage tank must meet the design criteria of the Colorado Department of Public Health and Environment, Water Quality Control Division.
- The water quality basins must have mosquito control responsibilities included as a part of the construction design and maintenance plan to help control mosquito breeding habitat and minimize the potential for West Nile Virus.
- The site is unmanned and does not require wastewater service.

Mike McCarthy  
El Paso County Public Health  
Environmental Health Division  
719.575.8602  
[mikemccarthy@elpasoco.com](mailto:mikemccarthy@elpasoco.com)  
20May2020