



# Site Plan\_V1.pdf Markup Summary

Locked (5)




**Subject:** Cloud+  
**Page Label:** 1  
**Lock:** Locked  
**Author:** dsdsevigny  
**Date:** 11/7/2019 8:51:03 AM  
**Status:**  
**Color:** ■  
**Layer:**  
**Space:**

Needs Clearance from Fire District




**Subject:** Text Box  
**Page Label:** 1  
**Lock:** Locked  
**Author:** dsdsevigny  
**Date:** 11/7/2019 8:51:05 AM  
**Status:**  
**Color:** ■  
**Layer:**  
**Space:**

Screening not depicted, a wire fence is not 100% opaque, please refer to Section 5.2.37 of the LDC for storage of vehicles. This is also a part of the Letter of Intent and how the applicant is intending to meet the Criteria of Approval.




**Subject:** Text Box  
**Page Label:** 1  
**Lock:** Locked  
**Author:** dsdsevigny  
**Date:** 11/7/2019 8:51:06 AM  
**Status:**  
**Color:** ■  
**Layer:**  
**Space:**

Letter of Intent indicates 2 full-time residences, site plan only shows one care-takers quarters.



**Subject:** Text Box  
**Page Label:** 1  
**Lock:** Locked  
**Author:** dsdsevigny  
**Date:** 11/7/2019 8:51:07 AM  
**Status:**  
**Color:** ■  
**Layer:**  
**Space:**

See comments on Letter of Intent in regards to signage. Only 1 per street frontage is permitted in the C-2 zoning



**Subject:** Cloud+  
**Page Label:** 1  
**Lock:** Locked  
**Author:** dsdsevigny  
**Date:** 11/7/2019 8:51:09 AM  
**Status:**  
**Color:** ■  
**Layer:**  
**Space:**

not mentioned anywhere in application