



ENTECH
 ENGINEERING, INC.
 505 Elkton Drive
 Colorado Springs, CO 80907
 (719) 531-5599 • (719) 531-5238 (fax)

Client: **FLRD #6**
 Project: **Forest Lakes Residential Development, Filing 6**
 Entech Job # **201326**

CONCRETE TEST

IT			Test #: 20		
Date: 5/6/2022	# of Specimens: 4	Specified Strength (psi): 4000	Time of Test: 10:40 AM	Hours Field Cured: 24	Lab Receive Date: 5/7/2022
Specimen Type		Test Type		Type of Cure	
Cylinders 4x8		Field		Lab	
Contractor: Trax Construction		Supplier: Transit Mix		Mix Design Number: T34592110	
Truck Number: 78		Ticket Number: 86590676		Batch Time: 9:58 AM	
Location: Curb & Gutter; Northwest corner of the intersection of Mesa Top Drive North & Mesa Top Drive South.					
Slump (in.): 2.0	Air (%): 5.4	Unit Weight (PCF): 136.0	Concrete Temp (°F): 72	Air Temp (°F): 61	
7-Day Strength	28-Day Strength	-Day Strength	56-Day Strength	-Day Strength	
5010					
Average: 5010	Average:	Average:	Average:	Average:	
Break Date: 5/13/2022	Break Date: 6/3/2022	Break Date:	Break Date:	Break Date:	
Remarks: 7 Day Results;					
Specifications: 4000 PSI, 4" Max Slump, 5-8% Air			Break Sequence: 1@7, 3@28		
Summary Comments: Trax Construction, Transit Mix					

Reviewed By: