



ENTECH
 ENGINEERING, INC.
 505 Elkton Drive
 Colorado Springs, CO 80907
 (719) 531-5599 • (719) 531-5238 (fax)

Client:	FLRD #6
Project:	Forest Lakes Residential Development, Filing 6
Entech Job #	201326

CONCRETE TEST

J. Barnhart			Test #: 22		
Date: 5/31/2022	# of Specimens: 4	Specified Strength (psi): 4500	Time of Test: 8:37 AM	Hours Field Cured: 24	Lab Receive Date: 6/1/2022
Specimen Type		Test Type		Type of Cure	
Cylinders 4x8		Field		Lab	
Contractor: Trax Construction		Supplier: Transit Mix		Mix Design Number: T34562110	
Truck Number: 26		Ticket Number: 86591847		Batch Time: 7:17 AM	

Location:
 Sidewalk; Directly in front of 4366 Mesa Top Drive.

Slump (in.): 0.5	Air (%): 4.0	Unit Weight (PCF): 144.8	Concrete Temp (°F): 77	Air Temp (°F): 51
7-Day Strength	28-Day Strength	-Day Strength	56-Day Strength	-Day Strength
5210				
Average: 5210	Average:	Average:	Average:	Average:
Break Date: 6/7/2022	Break Date: 6/28/2022	Break Date:	Break Date:	Break Date:

Remarks:
 7 Day Results; Low Air Recorded.

Specifications: 4500 PSI, 4" Max Slump, 5-8% Air	Break Sequence: 1@7, 3@28
---	------------------------------

Summary Comments:
 Trax Construction, Transit Mix

Reviewed By: *[Signature]*