



ENTECH
ENGINEERING, INC.

505 ELKTON DRIVE
COLORADO SPRINGS, CO 80907
PHONE (719) 531-5599
FAX (719) 531-5238

January 13, 2022

FLRD #6
2138 Flying Horse Club Drive
Colorado Springs, CO 80921

Attn: Jim Boulton

Re: Density Testing – Storm Sewer
Forest Lakes Residential Development, Filing 6
Colorado Springs, Colorado
Report No. 3, Tests 124 – 129

Dear Mr. Boulton,


As requested, personnel of Entech Engineering, Inc. have performed density testing at the above referenced site.


Density testing on this site was performed on December 16, 2021 and December 17, 2021. The density testing indicates that the materials have been adequately compacted at the depths and in the locations noted. Results of the density tests are enclosed with this letter.

We trust that this has provided you with the information you require. Should you have any questions or need further information, please do not hesitate to contact us.

Respectfully Submitted,

ENTECH ENGINEERING, INC.


Joseph C. Goode, Jr.
President



JCG/el

Enclosure

Entech Job No. 201326

F:\AA projects\2020\201326-FLRD-Forest Lakes F6-110-ConMat\201326_4cl3.doc

Client: FLRD #6	Entech Job #: 201326.4	Proctor Value Key: M = modified, ASTM D-1557
Project: Forest Lakes Residential Development, Filing 6	Tested By: J. Claton	S = standard, ASTM D-698
Subject: Storm Sewer	Report Date: 01-17-2022	T = AASHTO, T-180

Test #	Test Location	Testing Date	Percent Compaction	Percent Required	Percent Moisture	Soil Type	Proctor Type/Value	Pass/Fail
124	Main, Station 23 + 00 on Mesa Top Drive N, 4' below grade.	12/16/2021	96	95	7.6	SM	M - 130.3 @ 7.6	<input type="checkbox"/>
125	Main, Station 23 + 00 on Mesa Top Drive N, 2' below grade.	12/16/2021	97	95	7.4	SM	M - 130.3 @ 7.6	<input type="checkbox"/>
126	Main, Station 23 + 00 on Mesa Top Drive N, at grade.	12/16/2021	97	95	6.8	SM	M - 130.3 @ 7.6	<input type="checkbox"/>
127	Main, Station 20 + 50 on Mesa Top Drive N, 4' below grade.	12/17/2021	96	95	7.1	SM	M - 130.3 @ 7.6	<input type="checkbox"/>
128	Main, Station 20 + 50 on Mesa Top Drive N, 2' below grade.	12/17/2021	96	95	6.5	SM	M - 130.3 @ 7.6	<input type="checkbox"/>
129	Main, Station 20 + 50 on Mesa Top Drive N, at grade.	12/17/2021	97	95	6.2	SM	M - 130.3 @ 7.6	<input type="checkbox"/>

Comments:

Scope of Observation: PERIODIC; CONTRACTOR'S OR CLIENT'S REPRESENTATIVE ADVISED

All dimensions are approximate. Cl. = Centerline



ENTECH
ENGINEERING, INC.
505 Elkton Drive
Colorado Springs, CO 80907
(719) 531-5599 • (719) 531-5238 (fax)

FIELD DENSITY RESULTS

Joseph C. Goode, Jr., P.E.