



ENTECH
 ENGINEERING, INC.
 505 Elkton Drive
 Colorado Springs, CO 80907
 (719) 531-5599 • (719) 531-5238 (fax)

Client: **FLRD #6**
 Project: **Forest Lakes Residential Development, Filing 6**
 Entech Job # **201326**

CONCRETE TEST

J. Brunk			Test #: 19		
Date: 5/5/2022	# of Specimens: 4	Specified Strength (psi): 4000	Time of Test: 10:05 AM	Hours Field Cured: 24	Lab Receive Date: 5/6/2022
Specimen Type		Test Type		Type of Cure	
Cylinders 4x8		Field		Lab	
Contractor: Trax Construction		Supplier: Transit Mix		Mix Design Number: T34592110	
Truck Number: 10		Ticket Number: 86492420		Batch Time: 8:40 AM	

Location:
Curb & Gutter; GPS Coordinates: (39.06256° N, 104.91012° W)

Slump (in.): 2.0	Air (%): 5.0	Unit Weight (PCF): 140.2	Concrete Temp (°F): 70	Air Temp (°F): 45
7-Day Strength	28-Day Strength	-Day Strength	56-Day Strength	-Day Strength
4320				
Average: 4320	Average:	Average:	Average:	Average:
Break Date: 5/12/2022	Break Date: 6/2/2022	Break Date:	Break Date:	Break Date:

Remarks:
7 Day Results;

Specifications: **4000 PSI, 4" Max Slump, 5-8% Air** Break Sequence: **1@7, 3@28**

Summary Comments:
Trax Construction, Transit Mix

Reviewed By: