



ENTECH
 ENGINEERING, INC.
 505 Elkton Drive
 Colorado Springs, CO 80907
 (719) 531-5599 • (719) 531-5238 (fax)

Client: **FLRD #6**
 Project: **Forest Lakes Residential Development, Filing 6**
 Entech Job #: **201326**

CONCRETE TEST

VG			Test #: 18		
Date: 4/28/2022	# of Specimens: 4	Specified Strength (psi): 4500	Time of Test: 11:41 AM	Hours Field Cured: 120	Lab Receive Date: 5/3/2022
Specimen Type		Test Type		Type of Cure	
Cylinders 4x8		Field		Lab	
Contractor: Trax Construction		Supplier: Transit Mix		Mix Design Number: T34562110	
Truck Number: 86		Ticket Number: 86590243		Batch Time: 10:58 AM	

Location:
Curb & Gutter; 100' South & 3' East off of the Northwest corner of the intersection of Timber Trek Way & Mesa Top Drive.

Slump (in.): 2.0	Air (%): 6.1	Unit Weight (PCF): 141.2	Concrete Temp (°F): 71	Air Temp (°F): 66
-------------------------	---------------------	---------------------------------	-------------------------------	--------------------------

<i>7-Day Strength</i>	<i>28-Day Strength</i>	<i>-Day Strength</i>	<i>56-Day Strength</i>	<i>-Day Strength</i>
4180				
Average: 4180	Average:	Average:	Average:	Average:
Break Date: 5/5/2022	Break Date: 5/26/2022	Break Date:	Break Date:	Break Date:

Remarks:
7 Day Results;
Concrete used for the 7 day break had less than 48 hours curing in the lab.

Specifications: **4500 PSI, 4" Max Slump, 5-8% Air** Break Sequence: **1@7, 3@28**

Summary Comments:
Trax Construction, Transit Mix

Reviewed By: