



ENTECH
 ENGINEERING, INC.
 505 Elkton Drive
 Colorado Springs, CO 80907
 (719) 531-5599 • (719) 531-5238 (fax)

Client:	FLRD #6
Project:	Forest Lakes Residential Development, Filing 6
Entech Job #	201326

CONCRETE TEST

J. Barnhart			Test #:			29		
Date:	# of Specimens	Specified Strength (psi)	Time of Test	Hours Field Cured	Lab Receive Date:			
6/17/2022	4	4500	9:30 AM	24	6/18/2022			
Specimen Type			Test Type			Type of Cure		
Cylinders 4x8			Field			Lab		
Contractor:		Supplier:		Mix Design Number				
Trax Construction		Transit Mix		T34592110				
Truck Number		Ticket Number		Batch Time:				
73		86703512		8:05 AM				

Location:
 Curb & Gutter; 5' West off of the west end of the bridge on Mesa Top Drive.

Slump (in.):	Air (%):	Unit Weight (PCF):	Concrete Temp (°F)	Air Temp (°F)
2.5	4.8	142.7	82	81
7-Day Strength	28-Day Strength	-Day Strength	56-Day Strength	-Day Strength
5620				
Average:	Average:	Average:	Average:	Average:
5620				
Break Date:	Break Date:	Break Date:	Break Date:	Break Date:
6/24/2022	7/15/2022			

Remarks:
 7 Day Results.

Specifications: 4000 PSI, 5-8% Air Break Sequence: 1@7, 3@28

Summary Comments:
 Trax Construction, Transit Mix

Reviewed By: *[Signature]*