



**ENTECH**  
 ENGINEERING, INC.  
 505 Elkton Drive  
 Colorado Springs, CO 80907  
 (719) 531-5599 • (719) 531-5238 (fax)

Client:	FLRD #6
Project:	Forest Lakes Residential Development, Filing 6
Entech Job #	201326

**CONCRETE TEST**

VG			Test #: 17		
Date:	# of Specimens	Specified Strength (psi)	Time of Test	Hours Field Cured	Lab Receive Date:
4/28/2022	4	4500	8:00 AM	120	5/3/2022
<b>Specimen Type</b>		<b>Test Type</b>		<b>Type of Cure</b>	
<b>Cylinders 4x8</b>		<b>Field</b>		<b>Lab</b>	
Contractor:		Supplier:		Mix Design Number	
Trax Construction		Transit Mix		T34562110	
Truck Number		Ticket Number		Batch Time:	
73		86492095		7:06 AM	

Location:  
 Curb & Gutter; 30' South & 3' East off of the Northwest corner of the intersection of Timber Trek Way & Mesa Top Drive.

Slump (in.):	Air (%):	Unit Weight (PCF):	Concrete Temp (°F)	Air Temp (°F)
2.0	6.0	140.8	70	60
<b>7-Day Strength</b>	<b>28-Day Strength</b>	<b>-Day Strength</b>	<b>56-Day Strength</b>	<b>-Day Strength</b>
2280	4000		4940	
			4890	
Average:	Average:	Average:	Average:	Average:
2280	4000		4915	
Break Date:	Break Date:	Break Date:	Break Date:	Break Date:
5/5/2022	5/26/2022		6/23/2022	

Remarks:  
 56 Day Results  
 Concrete used for the 7 day break had less than 48 hours curing in the lab.

Specifications:	Break Sequence:
4500 PSI, 4" Max Slump, 5-8% Air	1@7, 1@28, 2@56
Summary Comments:	
Trax Construction, Transit Mix	

Reviewed By: *[Signature]*

